

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **December, 25**

System Name:		Reedsport 4100699					WTP : TP - Clear lake
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.27	0.27	0.27	0.27	0.27	0.27	0.42
2	0.27	0.26	0.26	0.26	0.27	0.27	0.46
3	0.27	0.27	0.27	0.26	0.27	0.30	0.46
4	0.26	0.26	0.27	0.28	0.27	0.28	0.54
5	0.26	0.26	0.26	0.38	0.29	0.27	0.45
6	0.28	0.27	0.27	0.28	0.26	0.27	0.47
7	0.26	0.29	0.73	0.37	0.29	0.28	0.47
8	0.30	0.28	0.28	0.28	0.30	0.31	0.53
9	0.29	0.28	0.33	0.31	0.32	0.31	0.59
10	0.31	0.69	0.34	0.33	0.30	0.30	0.52
11	0.31	0.30	0.30	0.30	0.30	0.77	0.54
12	0.31	0.31	0.30	0.30	0.29	0.29	0.61
13	0.29	0.28	0.27	0.29	0.27	0.28	0.44
14	0.27	0.28	0.27	0.27	0.28	0.27	0.33
15	0.27	0.27	0.27	0.29	0.31	0.31	0.37
16	0.30	0.34	0.29	0.29	0.28	0.27	0.48
17	0.42	0.43	0.39	0.35	0.34	0.32	0.81
18	0.33	0.33	0.33	0.85	0.54	0.49	0.81
19	0.50	0.51	0.50	0.30	0.29	0.29	0.67
20	0.45	0.47	0.49	0.47	0.42	0.47	0.77
21	0.42	0.41	0.41	0.45	0.40	0.40	0.49
22	0.39	0.40	0.41	0.40	0.40	0.42	0.45
23	0.40	0.40	0.39	0.39	0.38	0.36	0.54
24	0.37	0.41	0.48	0.36	0.36	0.38	0.44
25	0.35	0.36	0.35	0.38	0.37	0.38	0.47
26	0.37	0.36	0.35	0.35	0.46	0.46	0.41
27	0.35	0.34	0.34	0.35	0.35	0.34	0.44
28	0.38	0.43	0.36	0.33	0.37	0.35	0.46
29	0.32	0.32	0.32	0.35	0.33	0.33	0.47
30	0.33	0.33	0.33	0.33	0.34	0.34	0.49
31	0.33	0.34	0.34	0.37	0.34	0.34	0.50

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	yes	Yes	Yes
Notes:			
		SIGNATURE: <i>A. K. Wooley</i>	
		541-707-0283	1/7/2026 681921

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP- :
System Name: Reedsport

4100699
Month/Year: December,25

Disinfection *Giardia* Log
Inactiv:
1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.65	74	48.1	13.6	7.56	35.4	y	908.8
2	0.73	74	54.0	13.5	7.55	35.8	y	940
3	0.62	74	45.9	13.5	7.41	33.6	y	1452.2
4	0.71	74	52.5	13.5	7.37	33.4	y	1075.6
5	0.7	74	51.8	13.8	7.41	33.2	y	1069.9
6	0.71	74	52.5	13.9	7.42	33.1	y	1033.7
7	0.71	74	52.5	13.9	7.42	33.1	y	998.6
8	0.71	74	52.5	14.0	7.42	32.9	y	1127.2
9	0.67	74	49.6	13.4	7.39	33.7	y	913.9
10	0.53	74	39.2	13.8	7.40	32.4	y	1045.7
11	0.51	74	37.7	14.0	7.41	32.1	y	1155.8
12	0.52	74	38.5	13.6	7.39	32.7	y	1021.8
13	0.56	74	41.4	13.7	7.37	32.4	y	985.8
14	0.56	74	41.4	13.7	7.37	32.4	y	932
15	0.6	74	44.4	13.7	7.34	32.2	y	1092.4
16	0.65	74	48.1	13.7	7.62	35.9	y	1072.6
17	0.6	74	44.4	13.9	7.57	34.6	y	946.6
18	0.68	74	50.3	13.2	7.54	36.2	y	1003.7
19	0.68	74	50.3	13.8	7.51	34.4	y	924.4
20	0.67	74	49.6	13.6	7.46	34.2	y	946.5
21	0.67	74	49.6	13.6	7.46	34.2	y	1051.8
22	0.65	74	48.1	13.4	7.40	33.8	y	946.5
23	0.65	74	48.1	13.5	7.48	34.6	y	1060.8
24	0.7	74	51.8	13.9	7.46	33.6	y	933.4
25	0.71	74	52.5	12.9	7.43	35.6	y	893
26	0.69	74	51.1	12.7	7.41	35.7	y	920.4
27	0.67	74	49.6	12.6	7.37	35.3	y	949.1
28	0.67	74	49.6	12.6	7.37	35.3	y	983
29	0.65	74	48.1	12.5	7.32	34.8	y	912.6
30	0.62	74	45.9	12.1	7.36	36.6	y	1099.8
31	0.64	74	47.4	11.9	7.36	37.1	y	1013.4

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.


Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Reedsport ID# 41 00699 Month/Year: December,25
 Minimum UVT [%] during month: 4.95 ity sensor variation from reference sensor %: 2.04
 Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly	Minimum Intensity	All Lamps On?	Daily Water	Water outside	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[mW/cm^2]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	908.8	4.95	y	800,000	0	
2	940	4.95	y	500,000	0	
3	1452.2	4.95	y	600,000	0	
4	1075.6	4.95	y	600,000	0	
5	1069.9	4.95	y	600,000	0	
6	1033.7	4.95	y	600,000	0	
7	998.6	4.95	y	600,000	0	
8	1127.2	4.95	y	600,000	0	
9	913.9	4.95	y	600,000	0	
10	1045.3	4.95	y	600,000	0	
11	1155.8	4.95	y	500,000	0	
12	1021.8	4.95	y	600,000	0	
13	985.8	4.95	y	600,000	0	
14	932	4.95	y	600,000	0	
15	1093.4	4.95	y	600,000	0	
16	1072.6	4.95	y	600,000	0	
17	946.6	4.95	y	700,000	0	
18	1003.7	4.95	y	500,000	0	
19	924.4	4.95	y	600,000	0	
20	946.5	4.95	y	600,000	0	
21	1051.8	4.95	y	600,000	0	
22	946.5	4.95	y	600,000	0	
23	1060.8	4.95	y	600,000	0	
24	933.4	4.95	y	600,000	0	
25	893	4.95	y	600,000	0	
26	920.4	4.95	y	600,000	0	
27	949.1	4.95	y	600,000	0	
28	983	4.95	y	700,000	0	
29	912.6	4.95	y	600,000	0	
30	1099.8	4.95	y	600,000	0	
31	1013.4	4.95	y	500,000	0	
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form - UV and opt mod.doc

Signature:  Op Cert #: 681921 Date: 1/7/2026

Raw Water Fecal Coliform 6 Month Running Average Report

CITY OF REEDSPORT

PWS ID:4100699

Monthly Report

Raw Water Fecal Coliform Per 100ml

Date	Jul-25	Aug-25	Sep-25	Oct-25	Nov-25	Dec-25
1	0					0
2	2		0			2
3			0	0	2	
4		0	0		0	0
5		0				
6				0	6.8	
7	0	0		0		
8	2		0			0
9			14	0		0
10	2				4.5	
11		0	0		2	0
12		0				
13				0	11	
14	0	0		0		
15	3.6		4.5			0
16			0	0		0
17	0				2	
18		0	4.5		4.5	0
19		0				
20				0	1.8	
21	0	0		4.5		1.8
22	0		0			
23			11	2	2	7.8
24	4.5				0	
25		0	4.5		2	
26		2				2
27				0		
28	4.5	0		2		
29			4.5			0
30	2		0	0		0
31	0					
AVERAGE	1.471428571	0.166666667	3.071428571	0.653846154	3.216666667	0.971428571
6 MONTH AVERAGE ENDING					1.591910867	
SIGNED: Mike Dooley				1/7/2026		