

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Douglas
 Month/Year: January, 26
 WTP : TP - Clear lake

System Name:	Reedsport		4100699				WTP : TP - Clear lake	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.33	0.36	0.41	0.38	0.36	0.38	0.51	
2	0.38	0.37	0.37	0.37	0.37	0.37	0.52	
3	0.39	0.36	0.34	0.36	0.36	0.34	0.52	
4	0.35	0.36	0.35	0.37	0.35	0.36	0.55	
5	0.35	0.34	0.55	0.36	0.35	0.35	0.74	
6	0.36	0.35	0.34	0.34	0.33	0.35	0.57	
7	0.35	0.36	0.36	0.34	0.40	0.34	0.83	
8	0.35	0.35	0.32	0.33	0.32	0.33	0.38	
9	0.32	0.32	0.33	0.33	0.32	0.37	0.35	
10	0.33	0.32	0.31	0.31	0.31	0.31	0.35	
11	0.31	0.31	0.30	0.73	0.30	0.32	0.41	
12	0.32	0.30	0.37	0.30	0.30	0.39	0.35	
13	0.32	0.29	0.29	0.29	0.35	0.82	0.35	
14	0.29	0.29	0.38	0.30	0.30	0.30	0.40	
15	0.44	0.29	0.31	0.29	0.33	0.33	0.38	
16	0.29	0.30	0.29	0.28	0.33	0.33	0.36	
17	0.27	0.28	0.29	0.29	0.29	0.29	0.44	
18	0.30	0.29	0.29	0.29	0.31	0.30	0.41	
19	0.29	0.28	0.29	0.29	0.32	0.30	0.53	
20	0.29	0.30	0.30	0.27	0.28	0.29	0.40	
21	0.27	0.27	0.27	0.29	0.28	0.29	0.42	
22	0.28	0.29	0.27	0.28	0.29	0.31	0.40	
23	0.28	0.36	0.28	0.69	0.33	0.28	0.38	
24	0.26	0.26	0.26	0.28	0.27	0.28	0.42	
25	0.34	0.36	0.26	0.27	0.28	0.27	0.45	
26	0.35	0.40	0.27	0.26	0.26	0.27	0.39	
27	0.26	0.25	0.27	0.26	0.26	0.26	0.39	
28	0.27	0.26	0.26	0.26	0.26	0.26	0.37	
29	0.26	0.26	0.29	0.25	0.25	0.27	0.56	
30	0.28	0.27	0.26	0.27	0.26	0.31	0.43	
31	0.34	0.26	0.26	0.25	0.25	0.27	0.39	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? yes	Yes	Yes
Notes:	SIGNATURE: <i>Mike Woxley</i>	
	541-707-0283	
	2/4/2026 681921	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

Disinfection *Giardia* Log

System Name: Reedsport

4100699

Month/Year: January,26

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.68	74	50.3	12.6	7.35	35.1	y	1018
2	0.7	74	51.8	12.4	7.32	35.7	y	1066.1
3	0.67	74	49.6	12.2	7.40	37.0	y	916.2
4	0.67	74	49.6	12.2	7.40	37.0	y	1020.5
5	0.65	74	48.1	11.9	7.47	38.6	y	908.6
6	0.63	74	46.6	12.2	7.44	37.4	y	1012.9
7	0.63	74	46.6	12.1	7.49	38.3	y	993.4
8	0.63	74	46.6	12.0	7.47	38.3	y	1075.3
9	0.64	74	47.4	11.3	7.55	41.2	y	939.9
10	0.63	74	46.6	11.6	7.55	40.4	y	913.9
11	0.63	74	46.6	11.6	7.55	40.4	y	915.1
12	0.61	74	45.1	11.9	7.54	39.4	y	951.7
13	0.58	74	42.9	11.2	7.51	40.7	y	911.3
14	0.66	74	48.8	11.4	7.49	40.2	y	1009
15	0.72	74	53.3	11.5	7.50	40.4	y	956.9
16	0.65	74	48.1	11.7	7.58	40.6	y	988
17	0.65	74	48.1	11.4	7.54	40.9	y	1330.7
18	0.65	74	48.1	11.4	7.54	40.9	y	1088.1
19	0.65	74	48.1	11.0	7.50	41.4	y	936.1
20	0.65	74	48.1	11.2	7.31	38.2	y	1225.9
21	0.65	74	48.1	11.4	7.48	40.0	y	1051.7
22	0.64	74	47.4	11.1	7.49	40.9	y	1098
23	0.64	74	47.4	11.0	7.42	40.2	y	930.9
24	0.65	74	48.1	10.7	7.49	42.0	y	1007.6
25	0.65	74	48.1	10.7	7.49	42.0	y	957
26	0.65	74	48.1	10.4	7.55	43.8	y	1193
27	0.65	74	48.1	10.5	7.60	44.3	y	933.3
28	0.64	74	47.4	10.6	7.52	42.7	y	916.5
29	0.62	74	45.9	10.8	7.54	42.4	y	1018.6
30	0.65	74	48.1	10.8	7.60	43.4	y	1062.1
31	0.64	74	47.4	10.9	7.47	41.2	y	930.7

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality Data


System Name: Reedsport ID# 41 00699 Month/Year: January,26
 Minimum UVT [%] during month: 4.95 ity sensor variation from reference sensor %: 1.57

Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly [gpm/unit]	Minimum Intensity [^{mW} /cm ²]	All Lamps On? [Y or N]	Daily Water [gal]	Water outside [gal]	Cumulative % Off-Spec Water Produced
						(Mo. Sum (B)) ÷ (Mo. Sum (A)) * 100 [%]
1	1018	4.95	y	700,000	0	
2	1066.1	4.95	y	600,000	0	
3	916.2	4.95	y	600,000	0	
4	1020.5	4.95	y	600,000	0	
5	908.6	4.95	y	700,000	0	
6	1012.9	4.95	y	600,000	0	
7	993.4	4.95	y	600,000	0	
8	1075.3	4.95	y	600,000	0	
9	939.9	4.95	y	600,000	0	
10	913.9	4.95	y	600,000	0	
11	915.1	4.95	y	700,000	0	
12	951.7	4.95	y	600,000	0	
13	911.3	4.95	y	700,000	0	
14	1009	4.95	y	700,000	0	
15	956.9	4.95	y	500,000	0	
16	988	4.95	y	700,000	0	
17	1330.7	4.95	y	700,000	0	
18	1088.1	4.95	y	700,000	0	
19	936.1	4.95	y	700,000	0	
20	1225.9	4.95	y	600,000	0	
21	1051.7	4.95	y	600,000	0	
22	1098	4.95	y	600,000	0	
23	930.9	4.95	y	700,000	0	
24	1007.6	4.95	y	700,000	0	
25	957	4.95	y	600,000	0	
26	1193	4.95	y	600,000	0	
27	933.3	4.95	y	600,000	0	
28	916.5	4.95	y	700,000	0	
29	1018.6	4.95	y	600,000	0	
30	1062.1	4.95	y	700,000	0	
31	930.7	4.95	y	700,000	0	
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form - UV and opt mod.doc

Signature:



Op Cert #: 681921

Date: 2/4/2026


Raw Water Fecal Coliform 6 Month Running Average Report

CITY OF REEDSPORT

PWS ID:4100699

Monthly Report

Raw Water Fecal Coliform Per 100ml

Date	Aug-25	Sep-25	Oct-25	Nov-25	Dec-25	Jan-26
1					0	
2		0			2	
3		0	0	2		
4	0	0		0	0	
5	0					0
6			0	6.8		0
7	0		0			
8		0			0	0
9		14	0		0	
10				4.5		
11	0	0		2	0	
12	0					0
13			0	11		0
14	0		0			
15		4.5			0	0
16		0	0		0	
17				2		
18	0	4.5		4.5	0	
19	0					0
20			0	1.8		2
21	0		4.5		1.8	
22		0				0
23		11	2	2	7.8	
24				0		
25	0	4.5		2		
26	2				2	0
27			0			0
28	0		2			
29		4.5			0	4
30		0	0		0	
31						
AVERAGE	0.166666667	3.071428571	0.653846154	3.216666667	0.971428571	0.5
6 MONTH AVERAGE ENDING						1.430006105
SIGNED: 					2/4/2026	