

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Douglas**
 Month/Year: **February, 26**

System Name:		Reedsport 4100699					WTP : TP - Clear lake	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1	0.25	0.25	0.24	0.26	0.25	0.25	0.40	
2	0.26	0.27	0.26	0.25	0.27	0.25	0.37	
3	0.26	0.26	0.26	0.27	0.26	0.32	0.45	
4	0.33	0.25	0.25	0.27	0.25	0.25	0.36	
5	0.26	0.25	0.24	0.27	0.25	0.25	0.49	
6	0.64	0.27	0.25	0.25	0.25	0.26	0.40	
7	0.22	0.22	0.84	0.22	0.22	0.22	0.33	
8	0.24	0.23	0.23	0.24	0.23	0.23	0.30	
9	0.23	0.23	0.25	0.24	0.23	0.24	0.33	
10	0.25	0.24	0.24	0.70	0.26	0.24	0.35	
11	0.24	0.26	0.33	0.24	0.23	0.25	0.34	
12	0.23	0.24	0.23	0.29	0.23	0.25	0.38	
13	0.35	0.24	0.23	0.22	0.25	0.22	0.36	
14	0.22	0.22	0.23	0.22	0.21	0.24	0.34	
15	0.22	0.22	0.22	0.25	0.24	0.22	0.41	
16	0.25	0.23	0.22	0.22	0.23	0.22	0.32	
17	0.21	0.22	0.23	0.24	0.22	0.22	0.34	
18	0.22	0.22	0.21	0.24	0.23	0.22	0.50	
19	0.23	0.22	0.22	0.22	0.22	0.23	0.36	
20	0.22	0.22	0.21	0.22	0.21	0.21	0.33	
21	0.56	0.21	0.21	0.21	0.22	0.22	0.31	
22	0.21	0.21	0.22	0.22	0.21	0.25	0.31	
23	0.24	0.22	0.22	0.24	0.26	0.24	0.34	
24	0.25	0.32	0.23	0.22	0.28	0.24	0.41	
25	0.24	0.23	0.54	0.26	0.26	0.24	0.41	
26	0.27	0.23	0.25	0.26	0.25	0.24	0.50	
27	0.43	0.28	0.25	0.22	0.21	0.21	0.49	
28	0.22	0.22	0.22	0.22	0.21	0.20	0.35	
29								
30								
31								

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point \geq 0.2 mg/l? Yes
All daily turbidity readings \leq 5 NTU? yes		
Notes:		
	SIGNATURE: <i>Michael W. Wadley</i>	3/3/2026
	541-707-0283	681921

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :
 Disinfection *Giardia* Log
 Inactiv: 1.0

System Name: Reedsport 4100699 Month/Year: February, 26

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.64	74	47.4	10.9	7.40	40.2	y	1077.7
2	0.63	74	46.6	10.9	7.33	39.2	y	955.5
3	0.62	74	45.9	11.4	7.47	39.7	y	1177.9
4	0.68	74	50.3	11.7	7.59	40.9	y	979.8
5	0.63	74	46.6	10.8	7.64	43.9	y	1029.7
6	0.69	74	51.1	10.9	7.64	43.9	y	1028.4
7	0.69	74	51.1	11.3	7.64	42.8	y	1046.5
8	0.69	74	51.1	11.3	7.64	42.8	y	926.9
9	0.68	74	50.3	11.5	7.64	42.2	y	1059.6
10	0.62	74	45.9	11.0	7.53	41.7	y	988.2
11	0.64	74	47.4	11.1	7.48	40.8	y	1159.7
12	0.64	74	47.4	11.2	7.53	41.2	y	958
13	0.72	74	53.3	11.3	7.57	41.9	y	1324.5
14	0.7	74	51.8	11.4	7.57	41.5	y	899.6
15	0.7	74	51.8	11.4	7.57	41.5	y	1142.8
16	0.68	74	50.3	11.4	7.56	41.3	y	1008.9
17	0.67	74	49.6	10.6	7.39	41.0	y	978.9
18	0.69	74	51.1	10.5	7.41	41.6	y	994.5
19	0.68	74	50.3	10.4	7.41	41.8	y	903.5
20	0.51	74	37.7	10.5	7.50	42.1	y	1014
21	0.66	74	48.8	10.5	7.48	42.5	y	936
22	0.66	74	48.8	10.5	7.48	42.5	y	925.7
23	0.6	74	44.4	11.0	7.45	40.4	y	869.6
24	0.6	74	44.4	11.1	7.50	40.9	y	1128.5
25	0.58	74	42.9	10.8	7.47	41.2	y	1104.9
26	0.65	74	48.1	10.7	7.43	41.2	y	1111.9
27	0.64	74	47.4	10.5	7.44	41.8	y	864.5
28	0.65	74	48.1	10.3	7.44	42.4	y	1034.9
29		74					y	
30		74					y	
31		74					y	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Reedsport ID# 41 00699 Month/Year: February,26
 Minimum UVT [%] during month: 4.95 ity sensor variation from reference sensor %: 1.89
 Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly	Minimum Intensity	All Lamps On?	Daily Water	Water outside	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) + (Mo. Sum {A}) * 100 [%]
1	1077.7	4.95	y	600,000	0	
2	955.5	4.95	y	600,000	0	
3	1177.9	4.95	y	600,000	0	
4	979.8	4.95	y	600,000	0	
5	1029.7	4.95	y	700,000	0	
6	1028.4	4.95	y	600,000	0	
7	1046.5	4.95	y	700,000	0	
8	926.9	4.95	y	600,000	0	
9	1059.6	4.95	y	700,000	0	
10	988.2	4.95	y	600,000	0	
11	1159.7	4.95	y	500,000	0	
12	958	4.95	y	700,000	0	
13	1324.5	4.95	y	600,000	0	
14	899.6	4.95	y	600,000	0	
15	1142.8	4.95	y	600,000	0	
16	1008.9	4.95	y	700,000	0	
17	978.9	4.95	y	700,000	0	
18	994.5	4.95	y	700,000	0	
19	903.5	4.95	y	500,000	0	
20	1014	4.95	y	700,000	0	
21	936	4.95	y	700,000	0	
22	925.7	4.95	y	600,000	0	
23	869.6	4.95	y	600,000	0	
24	1128.5	4.95	y	600,000	0	
25	1104.9	4.95	y	700,000	0	
26	1111.9	4.95	y	500,000	0	
27	864.5	4.95	y	700,000	0	
28	1034.9	4.95	y	700,000	0	
29		4.95	y		0	
30		4.95	y		0	
31		4.95	y		0	
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 EAMC/forms/Turbidity Report Form – UV and opt mod.doc

Signature: Michael Wadesu Op Cert #: 681921 Date: 3/3/2026


Raw Water Fecal Coliform 6 Month Running Average Report

CITY OF REEDSPORT

PWS ID:4100699

Monthly Report

Raw Water Fecal Coliform Per 100ml

Date	Sep-25	Oct-25	Nov-25	Dec-25	Jan-26	Feb-26
1				0		
2	0			2		0
3	0	0	2			0
4	0		0	0		
5					0	0
6		0	6.8		0	
7		0				
8	0			0	0	
9	14	0		0		0
10			4.5			0
11	0		2	0		
12					0	0
13		0	11		0	
14		0				
15	4.5			0	0	
16	0	0		0		2
17			2			
18	4.5		4.5	0		
19					0	0
20		0	1.8		2	0
21		4.5		1.8		
22	0				0	
23	11	2	2	7.8		0
24			0			2
25	4.5		2			
26				2	0	0
27		0			0	
28		2				
29	4.5			0	4	
30	0	0		0		
31						
AVERAGE	3.071428571	0.653846154	3.216666667	0.971428571	0.5	0.333333333
6 MONTH AVERAGE ENDING						1.457783883
SIGNED: 					3/3/2026	