

OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Douglas
 Month/Year: March, 26

System Name: Reedsport 4100699 WTP : TP - Clear lake

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.21	0.20	0.20	0.38	0.21	0.20	0.24
2	0.19	0.20	0.20	0.20	0.23	0.21	0.27
3	0.21	0.20	0.21	0.19	0.18	0.18	0.24
4	0.18	0.20	0.19	0.19	0.19	0.20	0.23
5	0.19	0.19	0.19	0.20	0.20	0.20	0.28
6	0.20	0.20	0.19	0.19	0.21	0.23	0.26
7	0.20	0.19	0.19	0.19	0.65	0.21	0.23
8	0.20	0.19	0.18	0.18	0.18	0.19	0.22
9	0.19	0.19	0.18	0.20	0.19	0.19	0.23
10	0.31	0.18	0.17	0.81	0.18	0.19	0.22
11	0.17	0.17	0.19	0.18	0.19	0.19	0.31
12	0.19	0.19	0.18	0.18	0.46	0.19	0.21
13	0.19	0.19	0.19	0.19	0.19	0.19	0.21
14	0.19	0.19	0.19	0.20	0.19	0.56	0.22
15	0.54	0.19	0.18	0.47	0.36	0.19	0.21
16	0.20	0.20	0.19	0.19	0.20	0.20	0.28
17	0.19	0.19	0.20	0.19	0.20	0.19	0.24
18	0.19	0.20	0.24	0.49	0.17	0.21	0.24
19	0.19	0.18	0.18	0.19	0.18	0.20	0.27
20	0.21	0.19	0.19	0.18	0.20	0.19	0.28
21	0.18	0.18	0.23	0.18	0.20	0.19	0.34
22	0.19	0.18	0.17	0.17	0.18	0.18	0.34
23	0.19	0.18	0.18	0.17	0.17	0.17	0.31
24	0.16	0.16	0.96	0.17	0.17	0.28	0.29
25	0.18	0.17	0.17	0.21	0.18	0.17	0.36
26	0.30	0.24	0.17	0.17	0.17	0.18	0.32
27	0.18	0.17	0.17	0.17	0.19	0.19	0.35
28	0.40	0.21	0.18	0.16	0.17	0.17	0.35
29	0.17	0.17	0.17	0.16	0.16	0.18	0.27
30	0.22	0.17	0.17	0.17	0.19	0.17	0.30
31	0.17	0.17	0.17	0.16	0.17	0.20	0.32

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings \leq 1 NTU? ² yes All daily turbidity readings \leq 5 NTU? yes	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) Yes	All Cl2 residual at entry point \geq 0.2 mg/l? Yes
Notes:	SIGNATURE: <i>Mike Doolan</i> 04/07/2020	
	541-707-0283 681921	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: Reedsport

4100699

Month/Year: March,26

Disinfection *Giardia* Log

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.65	74	48.1	10.6	7.44	41.6	y	900.8
2	0.65	74	48.1	10.7	7.44	41.3	y	943.9
3	0.63	74	46.6	11.1	7.44	40.2	y	1199.9
4	0.63	74	46.6	11.4	7.53	40.6	y	1019.2
5	0.65	74	48.1	11.3	7.44	39.7	y	1015.3
6	0.66	74	48.8	11.2	7.43	39.9	y	1023.2
7	0.68	74	50.3	11.4	7.40	39.1	y	942.6
8	0.68	74	50.3	11.4	7.40	39.1	y	1041.3
9	0.7	74	51.8	11.5	7.37	38.5	y	1007.6
10	0.65	74	48.1	11.4	7.44	39.5	y	1006.3
11	0.67	74	49.6	11.8	7.55	40.0	y	976.1
12	0.63	74	46.6	11.5	7.58	41.1	y	939.9
13	0.66	74	48.8	11.5	7.58	41.2	y	876.2
14	0.66	74	48.8	11.4	7.54	40.9	y	941
15	0.66	74	48.8	11.4	7.54	40.9	y	919.1
16	0.65	74	48.1	11.3	7.49	40.4	y	960.5
17	0.62	74	45.9	11.8	7.56	40.0	y	999.6
18	0.69	74	51.1	11.8	7.46	38.9	y	997.3
19	0.62	74	45.9	11.7	7.51	39.5	y	931.6
20	0.65	74	48.1	12.0	7.50	38.8	y	1060.9
21	0.65	74	48.1	12.0	7.49	38.6	y	907.5
22	0.65	74	48.1	12.0	7.49	38.6	y	1003.7
23	0.64	74	47.4	12.0	7.48	38.4	y	1058.3
24	0.6	74	44.4	12.0	7.54	39.1	y	1074.7
25	0.58	74	42.9	12.3	7.62	39.3	y	900.9
26	0.67	74	49.6	12.0	7.61	40.4	y	873.6
27	0.7	74	51.8	11.9	7.62	40.9	y	948.1
28	0.63	74	46.6	12.1	7.58	39.5	y	963.1
29	0.63	74	46.6	12.1	7.58	39.5	y	1045.2
30	0.55	74	40.7	12.3	7.53	38.0	y	1249.1
31	0.59	74	43.7	12.5	7.68	39.5	y	925.6

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Raw Water Fecal Coliform 6 Month Running Average Report

CITY OF REEDSPORT

PWS ID:4100699

Monthly Report

Raw Water Fecal Coliform Per 100ml

Date	Oct-25	Nov-25	Dec-25	Jan-26	Feb-26	Mar-26
1			0			
2			2		0	0
3	0	2			0	0
4		0	0			
5				0	0	2
6	0	6.8		0		
7	0					
8			0	0		
9	0		0		0	0
10		4.5			0	0
11		2	0			
12				0	0	4.5
13	0	11		0		
14	0					
15			0	0		
16	0		0		2	4
17		2				0
18		4.5	0			
19				0	0	0
20	0	1.8		2	0	
21	4.5		1.8			
22				0		
23	2	2	7.8		0	0
24		0			2	0
25		2				
26			2	0	0	0
27	0			0		
28	2					
29			0	4		
30	0		0			0
31						0
AVERAGE	0.653846154	3.216666667	0.971428571	0.5	0.333333333	0.75
6 MONTH AVERAGE ENDING					1.070879121	
SIGNED: <i>Mike W. [Signature]</i>						4/7/2026


Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: Reedsport ID# 41 00699 Month/Year: March,2026
 Minimum UVT [%] during month: 4.95 ity sensor variation from reference sensor %: 1.96

Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly [gpm/unit]	Minimum Intensity [^{mW} /cm ²]	All Lamps On? [Y or N]	Daily Water [gal]	Water outside [gal]	Cumulative % Off-Spec Water Produced (Mo. Sum (B)) + (Mo. Sum (A)) * 100 [%]
1	900.8	4.95	y	600,000	0	
2	943.9	4.95	y	600,000	0	
3	1199.9	4.95	y	600,000	0	
4	1019.2	4.95	y	600,000	0	
5	1015.3	4.95	y	600,000	0	
6	1023.2	4.95	y	700,000	0	
7	942.6	4.95	y	700,000	0	
8	1041.3	4.95	y	600,000	0	
9	1007.6	4.95	y	600,000	0	
10	1006.3	4.95	y	600,000	0	
11	976.1	4.95	y	600,000	0	
12	939.9	4.95	y	600,000	0	
13	876.2	4.95	y	700,000	0	
14	941	4.95	y	600,000	0	
15	919.1	4.95	y	600,000	0	
16	960.5	4.95	y	700,000	0	
17	999.6	4.95	y	600,000	0	
18	997.3	4.95	y	600,000	0	
19	931.6	4.95	y	700,000	0	
20	1060.9	4.95	y	600,000	0	
21	907.5	4.95	y	600,000	0	
22	1003.7	4.95	y	600,000	0	
23	1058.3	4.95	y	700,000	0	
24	1074.7	4.95	y	700,000	0	
25	900.9	4.95	y	600,000	0	
26	873.6	4.95	y	600,000	0	
27	948.1	4.95	y	700,000	0	
28	963.1	4.95	y	700,000	0	
29	1045.2	4.95	y	700,000	0	
30	1249.4	4.95	y	600,000	0	
31	925.6	4.95	y	700,000	0	
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form - UV and opt mod.doc

Signature:  Op Cert #: 681921 Date: 4/7/2026