

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Jun-21

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
6/1/2021	5:00	0.91	447	408	8.6	7.7	53	67	YES
6/2/2021	15:00	0.86	311	269	9.2	7.7	51	96	YES
6/3/2021	10:00	0.84	404	338	9.5	7.6	49	74	YES
6/4/2021	15:00	0.73	316	229	8.9	7.5	49	95	YES
6/5/2021	17:00	0.52	385	200	8.5	7.5	48	78	YES
6/6/2021	9:00	0.45	368	167	7.7	7.5	50	82	YES
6/7/2021	11:00	0.42	256	109	7.5	7.5	51	117	YES
6/8/2021	8:00	0.45	405	182	8.1	7.5	48	74	YES
6/9/2021	15:00	0.39	353	136	7.4	7.5	51	85	YES
6/10/2021	6:00	0.37	448	165	8.2	7.5	48	67	YES
6/11/2021	18:00	0.38	401	151	8.2	7.5	48	75	YES
6/12/2021	19:00	0.45	440	200	8.4	7.5	48	68	YES
6/13/2021	9:00	0.44	358	157	8.6	7.5	47	84	YES
6/14/2021	3:00	0.41	462	191	9.0	7.4	45	65	YES
6/15/2021	20:00	0.40	391	156	9.2	7.5	45	77	YES
6/16/2021	11:00	0.39	460	179	9.1	7.5	45	65	YES
6/17/2021	12:00	0.41	367	150	9.2	7.5	46	82	YES
6/18/2021	19:00	0.42	435	185	9.6	7.5	44	69	YES
6/19/2021	13:00	0.43	316	135	9.3	7.6	46	95	YES
6/20/2021	18:00	0.45	329	147	9.8	7.6	45	91	YES
6/21/2021	18:00	0.46	233	106	10.2	7.6	45	129	YES
6/22/2021	9:00	0.41	336	138	10.9	7.6	41	89	YES
6/23/2021	9:00	0.38	337	129	10.7	7.5	41	89	YES
6/24/2021	10:00	0.38	353	133	11.1	7.5	40	85	YES
6/25/2021	19:00	0.38	326	124	11.2	7.6	41	92	YES
6/26/2021	9:00	0.36	316	115	11.8	7.6	39	95	YES
6/27/2021	10:00	0.37	306	114	12.2	7.6	39	98	YES
6/28/2021	18:00	0.36	326	118	12.8	7.6	37	92	YES
6/29/2021	8:00	0.37	316	118	12.7	7.7	38	95	YES
6/30/2021	17:00	0.36	333	121	11.8	7.6	40	90	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 7/6/2021 CERT # 3675