

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Sep-21

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
9/1/2021	16:00	0.82	390	320	9.9	7.7	48	77	YES
9/2/2021	15:00	0.82	313	255	8.9	7.7	53	96	YES
9/3/2021	9:00	0.80	405	326	9.8	7.7	48	74	YES
9/4/2021	16:00	0.82	341	281	9.2	7.7	52	88	YES
9/5/2021	11:00	0.75	300	226	9.7	7.7	49	100	YES
9/6/2021	12:00	0.74	316	232	10.2	7.7	47	95	YES
9/7/2021	15:00	0.73	479	350	10.6	7.7	45	63	YES
9/8/2021	17:00	0.73	423	308	10.8	7.7	45	71	YES
9/9/2021	19:00	0.74	574	423	10.7	7.7	45	52	YES
9/10/2021	17:00	0.72	515	373	10.2	7.7	47	58	YES
9/11/2021	11:00	0.73	529	387	9.8	7.7	48	57	YES
9/12/2021	14:00	0.72	416	298	9.7	7.7	49	72	YES
9/13/2021	14:00	0.70	565	395	9.4	7.7	49	53	YES
9/14/2021	10:00	0.68	523	355	8.8	7.8	53	57	YES
9/15/2021	21:00	1.01	596	603	9.7	7.7	50	50	YES
9/16/2021	9:00	0.98	503	493	7.8	7.7	58	60	YES
9/17/2021	21:00	0.46	485	221	9.0	7.7	50	62	YES
9/18/2021	11:00	1.00	513	512	9.3	7.7	52	59	YES
9/19/2021	20:00	0.77	542	415	8.9	7.6	50	55	YES
9/20/2021	18:00	0.76	532	406	8.8	7.7	51	56	YES
9/21/2021	21:00	0.77	393	301	8.7	7.6	51	76	YES
9/22/2021	6:00	0.94	434	406	9.3	7.6	50	69	YES
9/23/2021	11:00	1.02	474	481	9.3	7.6	51	63	YES
9/24/2021	11:00	1.03	520	534	9.4	7.7	51	58	YES
9/25/2021	11:00	1.00	480	478	9.8	7.6	49	63	YES
9/26/2021	9:00	1.02	567	579	9.6	7.7	50	53	YES
9/27/2021	17:00	1.02	703	715	9.6	7.7	50	43	YES
9/28/2021	16:00	0.90	549	495	8.8	7.7	52	55	YES
9/29/2021	11:00	0.81	536	434	8.4	7.6	52	56	YES
9/30/2021	9:00	0.83	556	462	8.6	7.6	51	54	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

5-Oct-21

CERT #

3675