

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Nov-21

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
11/1/2021	20:00	1.01	433	435	6.3	7.6	61	69	YES
11/2/2021	9:00	1.03	443	456	6.5	7.7	63	68	YES
11/3/2021	20:00	1.05	443	463	7.1	7.8	61	68	YES
11/4/2021	10:00	1.09	429	469	7.4	7.7	60	70	YES
11/5/2021	22:00	1.04	504	522	7.0	7.9	66	60	YES
11/6/2021	11:00	1.23	367	453	6.2	7.7	65	82	YES
11/7/2021	9:00	1.17	437	509	5.7	7.7	67	69	YES
11/8/2021	10:00	1.20	446	533	5.5	7.8	70	67	YES
11/9/2021	18:00	1.20	569	681	5.8	7.7	68	53	YES
11/10/2021	20:00	1.16	451	525	5.9	7.8	68	67	YES
11/11/2021	0:00	1.12	515	578	6.3	7.8	67	58	YES
11/12/2021	11:00	0.62	434	267	7.1	7.9	61	69	YES
11/13/2021	23:00	0.44	499	217	7.7	7.9	58	60	YES
11/14/2021	10:00	0.55	386	211	8.0	7.9	58	78	YES
11/15/2021	23:00	0.92	495	454	8.2	7.8	58	61	YES
11/16/2021	15:00	1.06	450	477	6.4	7.7	63	67	YES
11/17/2021	23:00	1.36	523	710	5.9	7.6	65	57	YES
11/18/2021	16:00	1.39	452	628	6.4	7.7	65	66	YES
11/19/2021	5:00	1.28	509	651	6.7	7.7	64	59	YES
11/20/2021	17:00	1.23	425	521	6.0	7.7	65	71	YES
11/21/2021	10:00	1.33	461	611	5.6	7.7	69	65	YES
11/22/2021	16:00	1.35	427	577	6.0	7.7	68	70	YES
11/23/2021	6:00	1.41	482	681	6.1	7.7	68	62	YES
11/24/2021	19:00	1.37	430	588	5.4	7.7	70	70	YES
11/25/2021	7:00	1.33	479	636	5.4	7.7	71	63	YES
11/26/2021	15:00	1.35	402	543	5.8	8.1	78	75	YES
11/27/2021	10:00	1.54	457	706	6.2	7.8	70	66	YES
11/28/2021	13:00	1.40	440	615	6.6	7.8	67	68	YES
11/29/2021	23:00	1.34	502	671	6.9	7.8	65	60	YES
11/30/2021	20:00	1.29	455	589	7.1	7.8	63	66	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 3-Dec CERT # 3675