



OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702  
 SURFACE WATER QUALITY DATA

Dec-21

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
12/1/2021	8:00	1.31	451	593	7.2	7.8	63	67	YES
12/2/2021	20:00	1.38	475	654	7.3	7.7	61	63	YES
12/3/2021	11:00	1.43	448	642	6.2	7.7	67	67	YES
12/4/2021	20:00	1.57	439	686	6.2	7.7	69	68	YES
12/5/2021	11:00	1.56	399	624	5.4	7.7	73	75	YES
12/6/2021	21:00	1.55	475	735	5.4	7.8	75	63	YES
12/7/2021	12:00	1.24	432	534	6.2	7.6	63	70	YES
12/8/2021	20:00	1.07	467	497	6.2	7.6	61	64	YES
12/9/2021	14:00	0.95	446	424	5.1	7.5	64	67	YES
12/10/2021	23:00	0.93	477	442	5.0	7.5	65	63	YES
12/11/2021	11:00	0.81	404	329	5.1	7.6	65	74	YES
12/12/2021	10:00	0.65	462	300	5.4	7.6	62	65	YES
12/13/2021	9:00	0.64	447	287	5.3	7.7	64	67	YES
12/14/2021	16:00	0.84	512	430	4.7	7.6	66	59	YES
12/15/2021	10:00	0.97	446	432	4.4	7.7	71	67	YES
12/16/2021	16:00	1.01	539	541	4.5	7.6	69	56	YES
12/17/2021	11:00	1.06	412	435	4.7	7.7	70	73	YES
12/18/2021	17:00	1.01	503	510	4.7	7.7	71	60	YES
12/19/2021	17:00	0.92	404	371	4.4	7.7	70	74	YES
12/20/2021	11:00	0.83	508	421	4.3	8.2	85	59	YES
12/21/2021	19:00	1.10	423	464	4.5	7.8	74	71	YES
12/22/2021	11:00	1.08	508	549	4.8	7.9	76	59	YES
12/23/2021	20:00	1.07	441	473	4.7	9.1	118	68	YES
12/24/2021	15:00	1.11	401	443	4.4	7.8	76	75	YES
12/25/2021	13:00	1.00	403	401	3.9	7.7	74	75	YES
12/26/2021	17:00	0.96	386	370	3.0	7.7	78	78	YES
12/27/2021	12:00	0.98	480	469	2.8	7.6	77	63	YES
12/28/2021	9:00	0.97	375	363	2.6	7.7	80	80	YES
12/29/2021	17:00	0.95	500	476	3.0	7.7	78	60	YES
12/30/2021	17:00	0.95	382	363	2.5	7.7	81	79	YES
12/31/2021	16:00	0.95	434	413	2.5	7.7	81	69	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262  
 SIGNATURE: David Jacob  
 PRINT NAME David Jacob

DATE 6-Jan-22 CERT # 3675