



OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702  
 SURFACE WATER QUALITY DATA

Feb-22

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
2/1/2022	7:00	0.71	416	296	3.4	7.5	70	72	YES
2/2/2022	20:00	0.73	442	320	3.2	7.5	72	68	YES
2/3/2022	8:00	0.70	437	305	3.2	7.5	71	69	YES
2/4/2022	19:00	0.69	427	296	3.4	7.6	71	70	YES
2/5/2022	10:00	0.70	399	278	3.5	7.6	71	75	YES
2/6/2022	18:00	0.69	438	304	3.6	7.6	71	69	YES
2/7/2022	10:00	0.57	422	241	3.7	7.6	69	71	YES
2/8/2022	20:00	0.56	465	260	3.9	7.6	68	65	YES
2/9/2022	11:00	0.72	435	314	3.9	7.6	70	69	YES
2/10/2022	20:00	0.74	555	411	4.1	7.6	68	54	YES
2/11/2022	11:00	0.72	424	306	4.1	7.6	69	71	YES
2/12/2022	17:00	0.73	453	330	4.2	7.6	68	66	YES
2/13/2022	10:00	0.73	392	287	4.2	7.6	69	77	YES
2/14/2022	9:00	0.72	523	374	4.2	7.7	70	57	YES
2/15/2022	13:00	0.69	431	296	4.1	7.5	66	70	YES
2/16/2022	16:00	0.63	411	259	4.1	7.6	67	73	YES
2/17/2022	15:00	0.59	392	231	4.1	7.6	67	77	YES
2/18/2022	8:00	0.62	424	262	4.1	7.6	67	71	YES
2/19/2022	20:00	0.62	470	292	4.1	7.6	68	64	YES
2/20/2022	9:00	0.65	476	307	3.8	7.5	68	63	YES
2/21/2022	15:00	0.62	393	243	3.3	7.5	69	76	YES
2/22/2022	4:00	0.61	492	298	2.2	7.5	73	61	YES
2/23/2022	18:00	0.65	415	270	0.9	7.5	82	72	YES
2/24/2022	8:00	0.65	407	266	1.3	7.6	81	74	YES
2/25/2022	17:00	0.69	396	273	1.7	7.6	80	76	YES
2/26/2022	11:00	0.70	376	262	2.2	7.6	78	80	YES
2/27/2022	17:00	0.65	416	269	2.7	7.6	75	72	YES
2/28/2022	9:00	0.51	403	204	3.0	7.7	74	74	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262  
 SIGNATURE: David Jacob  
 PRINT NAME: David Jacob

DATE: 9-Mar-22 CERT # 3675