

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Apr-22

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
4/1/2022	12:00	0.75	535	399	5.3	7.5	61	56	YES
4/2/2022	16:00	0.66	413	272	5.4	7.5	61	73	YES
4/3/2022	10:00	0.62	483	299	5.2	7.5	62	62	YES
4/4/2022	20:00	0.56	410	228	4.9	7.5	62	73	YES
4/5/2022	0:00	0.46	515	236	4.3	7.5	63	58	YES
4/6/2022	18:00	0.45	428	194	4.5	7.5	63	70	YES
4/7/2022	13:00	0.50	502	252	4.9	7.5	62	60	YES
4/8/2022	20:00	0.56	415	231	5.3	7.6	61	72	YES
4/9/2022	7:00	0.57	489	279	4.6	7.4	61	61	YES
4/10/2022	18:00	0.59	412	241	4.0	7.6	67	73	YES
4/11/2022	10:00	0.60	446	266	3.2	7.5	69	67	YES
4/12/2022	23:00	0.61	458	280	3.4	7.5	68	66	YES
4/13/2022	7:00	0.62	437	270	3.2	7.5	70	69	YES
4/14/2022	11:00	0.62	471	292	3.4	7.5	69	64	YES
4/15/2022	15:00	0.63	422	265	3.2	7.6	73	71	YES
4/16/2022	12:00	0.63	489	306	3.5	7.6	70	61	YES
4/17/2022	10:00	0.61	419	253	3.4	7.7	73	72	YES
4/18/2022	19:00	0.58	555	323	3.5	7.5	67	54	YES
4/19/2022	9:00	0.55	447	247	3.6	7.7	72	67	YES
4/20/2022	10:00	0.49	531	262	3.6	7.6	68	57	YES
4/21/2022	20:00	0.49	421	208	3.7	7.7	71	71	YES
4/22/2022	0:00	0.46	501	230	3.9	7.7	70	60	YES
4/23/2022	16:00	0.53	417	220	4.2	7.7	69	72	YES
4/24/2022	10:00	0.56	510	287	4.3	7.7	69	59	YES
4/25/2022	14:00	0.57	422	240	4.7	7.9	73	71	YES
4/26/2022	4:00	0.63	520	329	4.8	7.6	66	58	YES
4/27/2022	18:00	0.59	436	256	4.9	7.7	65	69	YES
4/28/2022	11:00	0.55	451	247	4.9	7.6	64	67	YES
4/29/2022	22:00	0.53	464	247	4.9	7.7	65	65	YES
4/30/2022	12:00	0.49	420	204	5.1	7.7	64	72	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME: David Jacob
 DATE: 4-May-22 CERT # 3675