

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Jun-22

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
6/1/2022	9:00	0.55	455	251	7.2	7.7	56	66	YES
6/2/2022	21:00	0.70	455	318	7.5	7.6	55	66	YES
6/3/2022	19:00	0.69	437	299	7.8	7.6	53	69	YES
6/4/2022	9:00	0.72	512	367	7.7	7.6	53	59	YES
6/5/2022	20:00	0.70	414	290	7.9	7.5	51	72	YES
6/6/2022	19:00	0.67	535	359	8.0	7.5	51	56	YES
6/7/2022	11:00	0.64	449	287	7.3	7.5	53	67	YES
6/8/2022	0:00	0.61	527	322	8.0	7.5	50	57	YES
6/9/2022	11:00	0.64	274	176	8.1	7.5	51	109	YES
6/10/2022	0:00	0.57	550	315	8.5	7.5	49	55	YES
6/11/2022	12:00	0.42	406	172	8.7	7.5	46	74	YES
6/12/2022	12:00	0.43	500	213	8.0	7.4	48	60	YES
6/13/2022	9:00	0.45	455	204	7.6	7.4	49	66	YES
6/14/2022	19:00	0.41	444	182	7.3	7.4	50	68	YES
6/15/2022	9:00	0.44	434	189	7.3	7.4	51	69	YES
6/16/2022	11:00	0.45	417	188	7.9	7.9	57	72	YES
6/17/2022	11:00	0.55	399	218	7.8	7.4	49	75	YES
6/18/2022	10:00	0.50	404	201	7.7	7.4	49	74	YES
6/19/2022	10:00	0.47	490	230	7.9	7.4	48	61	YES
6/20/2022	11:00	0.46	401	186	7.9	7.4	48	75	YES
6/21/2022	18:00	0.48	470	227	8.2	7.5	48	64	YES
6/22/2022	10:00	0.54	414	222	8.6	7.5	48	72	YES
6/23/2022	17:00	0.57	493	280	8.8	7.5	47	61	YES
6/24/2022	18:00	0.48	408	196	8.5	7.5	47	74	YES
6/25/2022	18:00	0.61	413	251	9.0	7.5	47	73	YES
6/26/2022	14:00	0.63	248	157	9.6	7.6	46	121	YES
6/27/2022	19:00	0.63	413	258	10.1	7.5	44	73	YES
6/28/2022	9:00	0.62	426	262	9.7	7.5	45	71	YES
6/29/2022	17:00	0.59	342	202	9.2	7.5	47	88	YES
6/30/2022	20:00	0.65	332	215	9.5	7.6	46	90	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 7/9/2022 CERT # 3675