

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Sep-22

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
9/1/2022	6:00	0.65	366	238	11.2	7.6	42	82	YES
9/2/2022	17:00	0.64	526	336	11.2	7.7	44	57	YES
9/3/2022	19:00	0.63	475	300	10.9	7.7	44	63	YES
9/4/2022	10:00	0.63	497	314	10.0	7.7	47	60	YES
9/5/2022	9:00	0.63	432	272	10.6	7.7	45	70	YES
9/6/2022	6:00	0.64	403	256	10.4	7.7	45	75	YES
9/7/2022	18:00	0.63	505	320	10.7	7.7	45	59	YES
9/8/2022	22:00	0.61	557	337	9.7	7.7	48	54	YES
9/9/2022	11:00	0.62	390	242	9.8	7.7	48	77	YES
9/10/2022	15:00	0.63	414	263	9.8	7.7	47	72	YES
9/11/2022	11:00	0.62	413	257	10.2	7.6	45	73	YES
9/12/2022	16:00	0.62	796	490	10.8	7.6	43	38	YES
9/13/2022	7:00	0.61	1136	691	10.9	7.6	42	26	YES
9/14/2022	18:00	0.60	829	498	10.7	7.6	43	36	YES
9/15/2022	19:00	0.60	566	340	10.1	7.6	46	53	YES
9/16/2022	18:00	0.60	640	386	9.7	7.7	48	47	YES
9/17/2022	15:00	0.63	512	323	9.4	7.7	49	59	YES
9/18/2022	9:00	0.58	563	325	9.2	7.7	49	53	YES
9/19/2022	20:00	0.57	645	369	9.3	7.6	48	47	YES
9/20/2022	17:00	0.57	531	302	9.7	7.6	47	57	YES
9/21/2022	12:00	0.53	714	379	9.5	7.6	47	42	YES
9/22/2022	9:00	0.52	699	362	9.3	7.6	48	43	YES
9/23/2022	13:00	0.51	822	419	9.1	7.6	48	37	YES
9/24/2022	10:00	0.50	535	268	8.9	7.6	49	56	YES
9/25/2022	9:00	0.45	655	295	9.4	7.6	47	46	YES
9/26/2022	17:00	0.55	495	270	9.8	7.6	46	61	YES
9/27/2022	16:00	0.56	706	397	10.3	7.6	44	43	YES
9/28/2022	19:00	0.55	593	325	9.8	7.6	46	51	YES
9/29/2022	14:00	0.52	852	443	9.7	7.6	46	35	YES
9/30/2022	18:00	0.47	621	294	9.7	7.6	45	48	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 4-Oct-22 CERT # 3675