

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Nov-22

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
11/1/2022	6:00	0.80	478	381	7.1	7.6	56	63	YES
11/2/2022	16:00	0.75	442	331	5.7	7.5	59	68	YES
11/3/2022	7:00	0.80	463	369	5.5	7.5	61	65	YES
11/4/2022	17:00	0.68	236	161	6.5	7.7	59	127	YES
11/5/2022	10:00	0.58	595	345	5.5	7.5	60	50	YES
11/6/2022	11:00	0.60	312	187	5.5	8.1	74	96	YES
11/7/2022	17:00	1.00	391	392	5.4	7.6	65	77	YES
11/8/2022	15:00	1.01	397	403	5.4	7.6	65	76	YES
11/9/2022	8:00	1.02	411	420	4.8	7.5	66	73	YES
11/10/2022	18:00	1.05	396	415	5.0	7.6	66	76	YES
11/11/2022	16:00	1.03	380	392	4.9	7.6	66	79	YES
11/12/2022	9:00	1.04	355	368	4.8	7.5	66	85	YES
11/13/2022	12:00	1.02	338	346	4.6	7.5	66	89	YES
11/14/2022	18:00	1.01	407	409	4.4	7.5	67	74	YES
11/15/2022	19:00	0.98	426	415	4.3	7.5	67	70	YES
11/16/2022	7:00	0.70	435	306	4.3	7.5	65	69	YES
11/17/2022	16:00	0.50	399	201	3.8	7.4	63	75	YES
11/18/2022	6:00	0.41	454	185	3.5	7.4	64	66	YES
11/19/2022	19:00	0.43	382	164	3.6	7.4	65	79	YES
11/20/2022	9:00	0.44	418	185	3.4	7.4	65	72	YES
11/21/2022	13:00	0.47	380	178	3.8	7.6	68	79	YES
11/22/2022	6:00	0.57	455	261	4.2	7.5	66	66	YES
11/23/2022	17:00	0.44	359	156	4.7	7.5	62	84	YES
11/24/2022	9:00	0.41	361	148	4.9	7.5	60	83	YES
11/25/2022	18:00	0.42	371	155	5.1	7.5	59	81	YES
11/26/2022	10:00	0.41	351	142	4.7	7.5	61	86	YES
11/27/2022	18:00	0.37	388	143	4.7	7.5	60	77	YES
11/28/2022	9:00	0.24	392	95	3.7	7.8	72	77	YES
11/29/2022	18:00	0.85	381	325	3.5	7.8	78	79	YES
11/30/2022	8:00	0.80	407	326	3.5	7.9	79	74	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

4-Dec-22

CERT #

3675