

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Apr-23

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
4/1/2023	17:00	0.80	375	299	3.1	8.0	85	80	YES
4/2/2023	9:00	0.92	453	417	2.9	7.8	81	66	YES
4/3/2023	16:00	0.92	411	378	2.7	7.8	83	73	YES
4/4/2023	7:00	0.97	429	414	2.7	7.8	83	70	YES
4/5/2023	17:00	0.93	345	319	2.7	7.8	84	87	YES
4/6/2023	17:00	0.89	293	261	2.9	7.8	82	102	YES
4/7/2023	23:00	0.84	299	251	3.1	7.8	80	100	YES
4/8/2023	11:00	0.82	290	238	3.3	7.8	80	103	YES
4/9/2023	12:00	0.89	305	272	3.6	7.8	77	98	YES
4/10/2023	10:00	0.85	313	267	3.9	7.8	75	96	YES
4/11/2023	12:00	0.82	219	180	3.8	7.8	76	137	YES
4/12/2023	18:00	0.82	325	266	4.0	7.7	73	92	YES
4/13/2023	17:00	0.85	325	277	3.7	7.8	76	92	YES
4/14/2023	13:00	0.94	301	282	3.7	8.2	89	100	YES
4/15/2023	13:00	1.21	349	424	3.9	7.8	81	86	YES
4/16/2023	9:00	1.05	364	381	4.1	7.8	77	83	YES
4/17/2023	11:00	0.99	435	432	4.2	7.8	75	69	YES
4/18/2023	20:00	0.99	359	354	4.0	7.8	76	84	YES
4/19/2023	7:00	1.02	356	362	3.8	7.8	77	84	YES
4/20/2023	21:00	1.01	432	438	3.8	7.7	76	70	YES
4/21/2023	11:00	0.93	405	375	3.8	7.8	77	74	YES
4/22/2023	12:00	0.87	435	378	4.2	7.8	73	69	YES
4/23/2023	20:00	0.87	408	353	4.6	7.7	71	74	YES
4/24/2023	10:00	0.90	373	334	4.8	7.8	71	81	YES
4/25/2023	15:00	0.88	377	333	4.8	7.8	70	80	YES
4/26/2023	13:00	0.93	377	350	5.1	7.7	69	80	YES
4/27/2023	11:00	0.90	441	397	5.3	7.5	62	68	YES
4/28/2023	19:00	0.86	380	328	5.7	7.7	64	79	YES
4/29/2023	19:00	0.83	437	363	5.8	7.6	63	69	YES
4/30/2023	19:00	0.82	384	313	6.0	7.5	60	78	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME: David Jacob

DATE: 4-May-22 CERT # 3675