

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Jun-23

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
6/1/2023	14:00	1.13	429	483	7.5	7.2	50	70	YES
6/2/2023	13:00	1.09	417	454	7.6	7.3	50	72	YES
6/3/2023	8:00	1.08	462	498	8.0	7.3	48	65	YES
6/4/2023	14:00	1.09	500	547	8.5	7.3	47	60	YES
6/5/2023	8:00	1.07	455	488	8.5	7.3	48	66	YES
6/6/2023	17:00	1.05	462	483	8.9	7.3	46	65	YES
6/7/2023	9:00	1.05	429	449	9.3	7.3	44	70	YES
6/8/2023	20:00	1.02	484	492	9.6	7.2	43	62	YES
6/9/2023	8:00	1.02	493	501	9.2	7.2	44	61	YES
6/10/2023	17:00	0.96	455	437	8.9	7.3	46	66	YES
6/11/2023	12:00	0.98	599	586	9.1	7.3	46	50	YES
6/12/2023	19:00	0.98	524	515	9.7	7.3	44	57	YES
6/13/2023	7:00	0.97	600	584	10.0	7.5	46	50	YES
6/14/2023	20:00	1.10	437	482	9.0	7.3	47	69	YES
6/15/2023	16:00	1.03	456	470	8.7	7.3	47	66	YES
6/16/2023	19:00	0.98	404	394	9.0	7.3	46	74	YES
6/17/2023	17:00	0.98	390	380	9.6	7.3	44	77	YES
6/18/2023	9:00	0.99	528	521	8.4	7.3	47	57	YES
6/19/2023	10:00	0.91	478	436	7.7	7.3	49	63	YES
6/20/2023	9:00	0.84	550	463	8.1	7.2	47	55	YES
6/21/2023	20:00	0.84	386	325	8.4	7.3	46	78	YES
6/22/2023	8:00	0.89	550	492	8.5	7.3	47	55	YES
6/23/2023	18:00	0.94	386	364	9.1	7.3	45	78	YES
6/24/2023	13:00	0.94	420	395	9.4	7.3	44	72	YES
6/25/2023	18:00	0.94	461	434	9.3	7.3	45	65	YES
6/26/2023	13:00	0.95	508	483	9.7	7.4	45	59	YES
6/27/2023	19:00	1.03	468	482	9.7	7.3	44	64	YES
6/28/2023	11:00	0.90	376	339	9.8	7.3	43	80	YES
6/29/2023	11:00	0.84	400	335	10.2	7.3	42	75	YES
6/30/2023	20:00	0.82	385	315	10.3	7.3	41	78	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME: David Jacob

DATE: 7/5/2023 CERT # 3675