

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Sep-23

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
9/1/2023	19:00	0.78	413	323	10.8	7.3	39	73	YES
9/2/2023	20:00	0.78	448	352	10.8	7.2	39	67	YES
9/3/2023	9:00	0.87	424	371	11.1	7.2	39	71	YES
9/4/2023	10:00	0.90	371	332	10.6	7.3	41	81	YES
9/5/2023	16:00	0.89	397	354	10.0	7.4	43	76	YES
9/6/2023	7:00	0.91	361	330	9.5	7.3	44	83	YES
9/7/2023	21:00	0.92	320	293	9.9	7.3	43	94	YES
9/8/2023	17:00	0.48	324	156	9.6	7.4	43	93	YES
9/9/2023	18:00	0.69	326	224	10.1	7.3	41	92	YES
9/10/2023	12:00	0.62	370	229	10.5	7.3	40	81	YES
9/11/2023	16:00	0.60	406	243	10.5	7.3	40	74	YES
9/12/2023	19:00	0.60	423	254	10.4	7.3	40	71	YES
9/13/2023	14:00	0.42	394	165	10.3	7.3	40	76	YES
9/14/2023	7:00	0.72	463	335	10.0	7.3	41	65	YES
9/15/2023	18:00	0.74	380	282	10.3	7.3	41	79	YES
9/16/2023	19:00	0.71	435	307	10.8	7.3	39	69	YES
9/17/2023	13:00	0.69	462	320	10.6	7.3	40	65	YES
9/18/2023	11:00	0.69	478	328	10.0	7.3	41	63	YES
9/19/2023	8:00	0.70	469	330	9.2	7.3	44	64	YES
9/20/2023	19:00	0.66	429	284	9.2	7.3	43	70	YES
9/21/2023	13:00	0.64	479	306	8.5	7.3	45	63	YES
9/22/2023	16:00	0.44	516	225	8.7	7.4	45	58	YES
9/23/2023	9:00	0.74	405	299	9.0	7.3	45	74	YES
9/24/2023	9:00	0.78	439	342	8.9	7.3	45	68	YES
9/25/2023	8:00	0.61	609	371	9.2	7.3	43	49	YES
9/26/2023	10:00	0.57	461	263	9.3	7.3	43	65	YES
9/27/2023	9:00	0.57	613	350	9.1	7.3	43	49	YES
9/28/2023	17:00	0.56	621	346	9.0	7.3	44	48	YES
9/29/2023	10:00	0.56	485	272	8.9	7.3	44	62	YES
9/30/2023	9:00	0.58	583	337	8.6	7.3	44	52	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 2-Oct-23 CERT # 3675