



OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702  
 SURFACE WATER QUALITY DATA

Nov-23

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
11/1/2023	12:00	0.83	417	345	5.9	7.3	55	72	YES
11/2/2023	18:00	0.38	555	210	6.4	7.3	51	54	YES
11/3/2023	18:00	0.26	340	89	7.2	7.6	53	88	YES
11/4/2023	11:00	0.60	321	192	7.8	7.4	50	93	YES
11/5/2023	11:00	0.50	273	135	8.1	7.4	47	110	YES
11/6/2023	13:00	0.79	334	264	8.0	7.3	48	90	YES
11/7/2023	8:00	0.67	418	278	7.5	7.3	49	72	YES
11/8/2023	17:00	0.65	409	266	7.3	7.1	46	73	YES
11/9/2023	18:00	0.84	350	294	6.2	7.2	52	86	YES
11/10/2023	18:00	1.10	390	427	6.7	7.2	52	77	YES
11/11/2023	13:00	1.05	376	394	6.7	7.2	52	80	YES
11/12/2023	11:00	0.98	326	318	6.8	7.2	52	92	YES
11/13/2023	23:00	0.99	391	387	6.9	7.3	53	77	YES
11/14/2023	10:00	1.08	395	427	6.3	7.2	54	76	YES
11/15/2023	15:00	1.13	365	413	6.8	7.3	53	82	YES
11/16/2023	23:00	1.08	390	420	7.0	7.3	52	77	YES
11/17/2023	13:00	1.02	410	419	6.4	7.2	52	73	YES
11/18/2023	22:00	1.00	370	371	6.1	7.2	53	81	YES
11/19/2023	9:00	0.78	325	253	6.2	7.2	52	92	YES
11/20/2023	11:00	0.76	403	306	5.5	7.2	54	74	YES
11/21/2023	11:00	0.79	328	259	5.7	7.2	55	92	YES
11/22/2023	6:00	0.89	364	324	6.2	7.3	54	83	YES
11/23/2023	10:00	0.89	383	340	5.6	7.2	56	78	YES
11/24/2023	10:00	0.95	362	344	4.7	7.3	60	83	YES
11/25/2023	10:00	1.12	361	405	4.0	7.3	64	83	YES
11/26/2023	10:00	1.24	349	433	3.8	7.3	67	86	YES
11/27/2023	7:00	1.25	410	513	4.0	7.3	66	73	YES
11/28/2023	7:00	1.25	280	350	3.7	7.3	68	107	YES
11/29/2023	23:00	1.25	394	491	3.6	7.3	69	76	YES
11/30/2023	15:00	1.26	413	520	4.0	7.3	67	73	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262  
 SIGNATURE: David Jacob  
 PRINT NAME: David Jacob

DATE: 4-Dec-23      CERT # 3675