

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Mar-24

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
3/1/2024	19:00	0.68	1079	735	3.8	7.4	64	28	YES
3/2/2024	7:00	0.80	1031	824	3.7	7.3	63	29	YES
3/3/2024	12:00	0.87	1190	1040	3.5	7.3	65	25	YES
3/4/2024	1:00	0.93	1205	1120	3.3	7.3	67	25	YES
3/5/2024	10:00	0.93	1255	1164	3.4	7.3	66	24	YES
3/6/2024	16:00	0.95	1224	1164	3.1	7.3	68	25	YES
3/7/2024	9:00	0.95	1200	1142	3.1	7.3	68	25	YES
3/8/2024	23:00	1.01	1149	1159	3.1	7.4	70	26	YES
3/9/2024	10:00	1.02	901	921	3.2	7.4	70	33	YES
3/10/2024	16:00	1.06	962	1015	3.4	7.5	71	31	YES
3/11/2024	8:00	1.28	1167	1489	3.6	7.5	74	26	YES
3/12/2024	11:00	1.12	1172	1308	3.7	7.4	68	26	YES
3/13/2024	19:00	1.01	1158	1166	3.7	7.4	68	26	YES
3/14/2024	13:00	1.02	1107	1134	3.6	7.4	69	27	YES
3/15/2024	22:00	1.17	1145	1334	3.7	7.4	69	26	YES
3/16/2024	8:00	1.18	1042	1226	4.0	7.4	68	29	YES
3/17/2024	17:00	1.13	1145	1295	4.3	7.4	66	26	YES
3/18/2024	15:00	1.09	1176	1281	4.5	7.4	64	26	YES
3/19/2024	13:00	0.98	1195	1171	4.8	7.4	62	25	YES
3/20/2024	23:00	0.97	1230	1186	5.1	7.3	60	24	YES
3/21/2024	9:00	0.96	990	950	5.2	7.4	61	30	YES
3/22/2024	17:00	0.83	1000	832	5.3	7.4	60	30	YES
3/23/2024	23:00	0.85	917	775	5.5	7.4	58	33	YES
3/24/2024	9:00	0.85	880	743	5.4	7.4	58	34	YES
3/25/2024	15:00	0.85	940	798	5.4	7.4	58	32	YES
3/26/2024	2:00	0.35	1145	396	5.3	7.7	62	26	YES
3/27/2024	11:00	1.52	1190	1814	5.3	7.6	70	25	YES
3/28/2024	18:00	1.25	1200	1502	5.3	7.4	63	25	YES
3/29/2024	18:00	1.11	1034	1147	5.2	7.4	62	29	YES
3/30/2024	23:00	1.01	1154	1162	5.2	7.4	60	26	YES
3/31/2024	9:00	1.00	1049	1044	5.3	7.4	60	29	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME: David Jacob

DATE: 1-Apr-24 CERT # 3675