

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Apr-24

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
4/1/2024	11:00	0.99	1149	1140	5.3	7.4	61	26	YES
4/2/2024	18:00	0.99	783	772	5.6	7.4	59	38	YES
4/3/2024	20:00	0.97	1141	1106	5.8	7.3	57	26	YES
4/4/2024	7:00	1.01	1124	1136	5.0	7.3	61	27	YES
4/5/2024	16:00	1.04	1200	1246	4.7	7.3	62	25	YES
4/6/2024	21:00	1.01	1167	1177	4.8	7.4	62	26	YES
4/7/2024	9:00	0.97	1056	1026	4.9	7.4	63	28	YES
4/8/2024	16:00	0.98	1145	1121	5.0	7.7	70	26	YES
4/9/2024	0:00	1.42	1224	1733	5.2	7.7	71	25	YES
4/10/2024	12:00	1.22	1230	1498	5.3	7.6	67	24	YES
4/11/2024	23:00	1.01	1095	1103	5.7	7.4	58	27	YES
4/12/2024	10:00	0.91	935	852	5.8	7.5	60	32	YES
4/13/2024	12:00	0.91	1007	917	6.0	7.5	58	30	YES
4/14/2024	0:00	0.97	980	952	6.3	7.4	56	31	YES
4/15/2024	10:00	0.91	1124	1027	6.2	7.3	55	27	YES
4/16/2024	19:00	0.91	1163	1056	5.6	7.3	57	26	YES
4/17/2024	0:00	0.93	1124	1045	5.2	7.3	59	27	YES
4/18/2024	11:00	0.93	1190	1107	5.2	7.4	61	25	YES
4/19/2024	18:00	0.95	1154	1101	5.5	7.4	60	26	YES
4/20/2024	11:00	0.98	1049	1023	5.7	7.4	59	29	YES
4/21/2024	13:00	0.99	1124	1116	5.9	7.4	59	27	YES
4/22/2024	14:00	1.02	1045	1062	5.4	7.4	61	29	YES
4/23/2024	23:00	1.02	1190	1218	5.9	7.7	65	25	YES
4/24/2024	7:00	1.23	1017	1251	6.2	7.6	64	30	YES
4/25/2024	17:00	1.95	1111	2168	6.4	7.7	70	27	YES
4/26/2024	9:00	1.69	1128	1909	6.5	7.7	68	27	YES
4/27/2024	18:00	1.83	1163	2126	6.5	7.7	69	26	YES
4/28/2024	23:00	1.49	1107	1644	6.5	7.5	61	27	YES
4/29/2024	9:00	1.07	1060	1135	5.4	7.4	62	28	YES
4/30/2024	20:00	0.78	1103	857	5.3	7.2	56	27	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME: David Jacob

DATE: 5-May-24 CERT # 3675