

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Jun-24

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
6/1/2024	8:00	0.80	576	462	7.6	7.3	50	52	YES
6/2/2024	9:00	0.77	587	453	8.1	7.3	47	51	YES
6/3/2024	12:00	0.54	600	326	8.2	7.2	45	50	YES
6/4/2024	0:00	0.54	596	322	7.9	7.3	46	50	YES
6/5/2024	9:00	0.56	542	305	8.2	7.3	46	55	YES
6/6/2024	20:00	0.70	539	376	8.1	7.3	47	56	YES
6/7/2024	9:00	0.79	546	430	8.5	7.3	46	55	YES
6/8/2024	16:00	0.41	574	236	9.0	7.7	49	52	YES
6/9/2024	9:00	1.69	539	909	9.2	7.6	54	56	YES
6/10/2024	11:00	0.75	673	505	9.2	7.2	43	45	YES
6/11/2024	8:00	0.61	464	281	9.2	7.2	41	65	YES
6/12/2024	18:00	0.57	479	271	9.3	7.1	40	63	YES
6/13/2024	18:00	0.52	480	250	8.9	7.2	42	63	YES
6/14/2024	13:00	0.54	455	245	8.7	7.2	42	66	YES
6/15/2024	6:00	0.67	583	390	8.7	7.1	42	52	YES
6/16/2024	8:00	0.63	588	370	7.9	7.2	45	51	YES
6/17/2024	19:00	0.62	595	369	8.1	7.2	45	50	YES
6/18/2024	0:00	0.69	633	434	8.2	7.2	45	47	YES
6/19/2024	8:00	0.71	658	466	8.4	7.2	44	46	YES
6/20/2024	17:00	0.76	664	502	8.6	7.6	50	45	YES
6/21/2024	19:00	1.28	693	887	9.3	7.4	48	43	YES
6/22/2024	11:00	1.31	456	597	9.8	7.3	44	66	YES
6/23/2024	14:00	1.12	471	528	10.0	7.2	42	64	YES
6/24/2024	18:00	1.06	461	490	9.4	7.2	44	65	YES
6/25/2024	11:00	1.04	455	475	9.3	7.3	44	66	YES
6/26/2024	8:00	1.03	478	495	9.9	7.2	42	63	YES
6/27/2024	8:00	1.05	616	644	9.7	7.2	42	49	YES
6/28/2024	15:00	1.06	677	718	9.6	7.3	45	44	YES
6/29/2024	18:00	1.10	625	687	9.5	7.3	44	48	YES
6/30/2024	19:00	1.09	452	491	10.0	7.3	43	66	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME: David Jacob

DATE: 7/5/2023 CERT # 3675