

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Sep-24

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
9/1/2024	8:00	0.79	571	453	10.0	7.4	43	53	YES
9/2/2024	18:00	0.79	628	496	10.0	7.4	43	48	YES
9/3/2024	18:00	0.83	589	492	10.0	7.4	44	51	YES
9/4/2024	13:00	0.85	534	453	10.0	7.3	42	56	YES
9/5/2024	6:00	0.85	538	456	10.0	7.3	42	56	YES
9/6/2024	8:00	0.83	564	469	9.0	7.4	47	53	YES
9/7/2024	19:00	0.88	532	466	9.0	7.4	47	56	YES
9/8/2024	0:00	0.80	501	401	9.0	7.4	46	60	YES
9/9/2024	8:00	0.75	517	388	9.0	7.5	48	58	YES
9/10/2024	17:00	0.65	526	339	10.0	7.4	43	57	YES
9/11/2024	19:00	0.62	529	330	10.0	7.4	43	57	YES
9/12/2024	19:00	0.50	518	256	9.0	7.5	46	58	YES
9/13/2024	2:00	0.48	524	252	9.0	7.4	45	57	YES
9/14/2024	20:00	0.51	557	281	9.0	7.5	46	54	YES
9/15/2024	17:00	0.50	524	261	9.0	7.4	45	57	YES
9/16/2024	9:00	0.49	718	355	8.0	7.5	50	42	YES
9/17/2024	13:00	0.52	730	381	8.0	7.5	50	41	YES
9/18/2024	0:00	0.56	698	387	8.0	7.3	46	43	YES
9/19/2024	14:00	0.57	804	460	8.0	7.4	48	37	YES
9/20/2024	17:00	0.59	656	388	8.0	7.4	48	46	YES
9/21/2024	12:00	0.59	815	479	7.0	7.3	50	37	YES
9/22/2024	17:00	0.57	637	362	8.0	7.4	48	47	YES
9/23/2024	20:00	0.57	648	368	8.0	7.4	48	46	YES
9/24/2024	1:00	0.59	792	469	8.0	7.3	47	38	YES
9/25/2024	10:00	0.77	659	505	8.0	7.4	49	46	YES
9/26/2024	19:00	0.63	589	370	8.0	7.3	47	51	YES
9/27/2024	9:00	0.58	543	316	9.0	7.3	44	55	YES
9/28/2024	16:00	0.57	600	340	9.0	7.4	45	50	YES
9/29/2024	0:00	0.56	701	395	8.0	7.4	48	43	YES
9/30/2024	15:00	0.62	685	424	8.0	7.4	49	44	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

6-Oct-24

CERT #

3675