



OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702  
 SURFACE WATER QUALITY DATA

Oct-24

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
10/1/2024	0:00	0.64	450	288	9	7.5	47	67	YES
10/2/2024	0:00	0.64	497	317	9	7.6	51	60	YES
10/3/2024	0:00	0.65	448	292	9	7.5	49	67	YES
10/4/2024	1:00	0.64	463	297	8	7.5	50	65	YES
10/5/2024	0:00	0.61	505	306	7	7.6	56	59	YES
10/6/2024	0:00	0.63	467	293	7	7.5	54	64	YES
10/7/2024	0:00	0.71	500	353	8	7.8	57	60	YES
10/8/2024	0:00	0.73	454	333	8	7.5	51	66	YES
10/9/2024	17:00	0.75	467	348	8	7.8	57	64	YES
10/10/2024	0:00	0.75	498	374	7	7.5	55	60	YES
10/11/2024	1:00	0.77	457	353	7	7.8	61	66	YES
10/12/2024	0:00	0.76	423	319	7	7.5	55	71	YES
10/13/2024	0:00	0.76	371	280	6	7.8	65	81	YES
10/14/2024	0:00	0.74	388	288	6	7.5	58	77	YES
10/15/2024	0:00	0.68	485	330	7	7.9	63	62	YES
10/16/2024	0:00	1.25	508	636	7	7.6	60	59	YES
10/17/2024	11:00	0.79	468	371	7	8.0	66	64	YES
10/18/2024	18:00	0.65	443	288	7	7.5	54	68	YES
10/19/2024	2:00	0.58	475	274	7	7.5	54	63	YES
10/20/2024	8:00	0.52	449	234	5	8.1	76	67	YES
10/21/2024	11:00	0.54	446	243	7	8.3	71	67	YES
10/22/2024	7:00	0.45	674	303	7	8.1	65	45	YES
10/23/2024	9:00	0.45	505	226	5	7.4	58	59	YES
10/24/2024	19:00	0.50	501	248	7	6.5	37	60	YES
10/25/2024	20:00	0.56	875	493	7	7.1	46	34	YES
10/26/2024	9:00	0.62	476	295	6	7.2	52	63	YES
10/27/2024	12:00	0.67	475	320	6	7.6	60	63	YES
10/28/2024	16:00	0.54	480	261	5	7.5	61	63	YES
10/29/2024	8:00	0.34	498	171	5	7.2	54	60	YES
10/30/2024	9:00	0.33	701	229	5	7.1	52	43	YES
10/31/2024	10:00	0.45	824	367	6	6.9	46	36	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262  
 SIGNATURE: David Jacob  
 PRINT NAME: David Jacob

DATE: 3-Nov-24      CERT # 3675