



OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702  
 SURFACE WATER QUALITY DATA

Jan-25

DATE	TIME	CHLORINE RESIDUAL	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRED	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
1/1/2025	22:00	1.77	532	943	5.2	7.4	67	56	YES
1/2/2025	21:00	1.48	454	671	5.2	7.4	65	66	YES
1/3/2025	22:00	1.35	485	654	5.2	7.3	61	62	YES
1/4/2025	11:00	1.32	425	562	5.3	7.6	68	71	YES
1/5/2025	21:00	1.28	485	621	5.4	7.4	62	62	YES
1/6/2025	10:00	1.28	470	603	5.6	7.4	62	64	YES
1/7/2025	21:00	1.32	520	686	5.3	7.5	65	58	YES
1/8/2025	12:00	1.37	499	684	5.3	7.5	66	60	YES
1/9/2025	21:00	1.39	527	734	5.3	7.4	64	57	YES
1/10/2025	12:00	1.41	500	706	5.3	7.3	62	60	YES
1/11/2025	22:00	1.42	471	668	5.2	7.3	62	64	YES
1/12/2025	9:00	1.42	453	641	5.0	7.6	70	66	YES
1/13/2025	8:00	1.46	658	963	4.6	7.7	75	46	YES
1/14/2025	12:00	0.76	536	409	4.6	7.7	69	56	YES
1/15/2025	7:00	0.95	728	689	4.6	7.6	68	41	YES
1/16/2025	16:00	1.66	555	921	4.6	7.6	74	54	YES
1/17/2025	0:00	1.49	626	936	4.5	7.5	71	48	YES
1/18/2025	17:00	1.29	487	629	4.0	7.5	71	62	YES
1/19/2025	8:00	1.16	492	572	3.6	7.4	70	61	YES
1/20/2025	11:00	1.12	503	562	3.3	7.4	71	60	YES
1/21/2025	7:00	1.09	560	612	3.3	7.4	70	54	YES
1/22/2025	19:00	1.08	566	612	3.6	7.6	74	53	YES
1/23/2025	8:00	1.10	569	624	3.7	7.4	69	53	YES
1/24/2025	20:00	1.09	501	548	3.8	7.4	68	60	YES
1/25/2025	9:00	1.10	474	521	3.3	7.5	73	63	YES
1/26/2025	12:00	1.14	444	505	3.0	7.5	75	68	YES
1/27/2025	5:00	1.17	602	704	3.0	7.5	75	50	YES
1/28/2025	13:00	1.21	519	626	2.9	7.4	73	58	YES
1/29/2025	21:00	1.26	594	747	3.0	7.4	73	51	YES
1/30/2025	20:00	1.49	467	697	3.1	7.3	72	64	YES
1/31/2025	0:00	0.58	552	322	3.1	7.3	65	54	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262  
 SIGNATURE: David Jacob  
 PRINT NAME David Jacob

DATE 5-Feb-25 CERT # 3675