

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Feb-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
2/1/2025	17:00	1.55	467	725	3.4	7.4	74	64	YES
2/2/2025	7:00	1.34	520	699	3.2	7.3	70	58	YES
2/3/2025	14:00	1.33	488	649	2.9	7.3	72	62	YES
2/4/2025	1:00	1.34	640	858	2.9	7.4	75	47	YES
2/5/2025	9:00	1.35	531	716	2.6	7.5	79	57	YES
2/6/2025	0:00	1.37	606	828	2.6	7.4	76	50	YES
2/7/2025	17:00	1.38	471	648	2.5	7.4	77	64	YES
2/8/2025	8:00	1.39	524	728	2.5	7.3	74	57	YES
2/9/2025	17:00	1.41	476	671	2.5	7.5	80	63	YES
2/10/2025	1:00	1.40	617	864	2.2	7.4	79	49	YES
2/11/2025	8:00	0.94	518	487	1.3	7.4	79	58	YES
2/12/2025	0:00	0.94	591	555	1.1	7.3	78	51	YES
2/13/2025	10:00	1.56	485	757	1.1	7.5	90	62	YES
2/14/2025	21:00	0.67	440	296	1.2	7.4	77	68	YES
2/15/2025	16:00	1.61	447	719	1.6	7.3	81	67	YES
2/16/2025	14:00	1.34	437	587	2.0	7.4	79	69	YES
2/17/2025	18:00	1.05	399	418	2.1	7.5	79	75	YES
2/18/2025	8:00	0.87	409	355	2.5	7.4	72	73	YES
2/19/2025	19:00	0.84	418	352	2.8	7.4	71	72	YES
2/20/2025	7:00	0.81	444	359	3.0	7.3	67	68	YES
2/21/2025	19:00	0.83	414	343	3.1	7.4	69	73	YES
2/22/2025	7:00	0.92	507	467	3.5	7.5	71	59	YES
2/23/2025	9:00	0.76	425	322	3.7	7.4	66	71	YES
2/24/2025	0:00	0.61	513	315	3.8	7.4	64	59	YES
2/25/2025	11:00	0.66	464	306	4.2	7.5	65	65	YES
2/26/2025	18:00	1.39	613	851	4.2	7.4	69	49	YES
2/27/2025	9:00	1.47	457	670	4.5	7.5	70	66	YES
2/28/2025	21:00	1.37	465	635	4.7	7.3	64	65	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 2-Mar-25 CERT # 3675