

Apr-25

[illegible]

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
SURFACE WATER QUALITY DATA

Apr-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
4/1/2025	8:00	1.10	525	577	5.1	7.1	55	57	YES
4/2/2025	23:00	1.00	595	595	5.2	6.8	50	50	YES
4/3/2025	12:00	1.20	515	617	5.0	7.1	57	58	YES
4/4/2025	8:00	1.00	666	666	4.9	6.8	51	45	YES
4/5/2025	10:00	1.05	473	496	5.1	7.1	55	63	YES
4/6/2025	0:00	1.06	610	646	5.4	7.0	53	49	YES
4/7/2025	19:00	1.04	509	529	5.8	7.1	52	59	YES
4/8/2025	8:00	1.00	781	781	5.9	6.8	47	38	YES
4/9/2025	21:00	1.06	517	548	5.9	7.0	51	58	YES
4/10/2025	0:00	1.12	645	722	6.0	7.0	51	47	YES
4/11/2025	16:00	1.00	520	520	6.3	7.0	49	58	YES
4/12/2025	8:00	1.01	512	519	5.9	7.0	51	59	YES
4/13/2025	16:00	1.04	497	518	5.8	7.1	52	60	YES
4/14/2025	7:00	1.06	557	592	5.8	7.0	50	54	YES
4/15/2025	20:00	1.11	523	583	5.9	6.9	49	57	YES
4/16/2025	9:00	1.04	518	540	6.3	7.0	49	58	YES
4/17/2025	20:00	1.01	543	550	6.3	6.8	46	55	YES
4/18/2025	10:00	1.00	538	537	6.3	7.0	49	56	YES
4/19/2025	20:00	1.00	499	500	6.4	6.9	47	60	YES
4/20/2025	10:00	1.01	496	500	6.3	7.0	50	60	YES
4/21/2025	9:00	1.02	667	683	6.3	6.8	46	45	YES
4/22/2025	12:00	1.01	508	515	6.0	7.1	52	59	YES
4/23/2025	23:00	1.04	605	629	6.2	6.8	47	50	YES
4/24/2025	20:00	1.04	499	519	6.2	7.1	51	60	YES
4/25/2025	0:00	1.09	570	623	6.4	7.0	49	53	YES
4/26/2025	19:00	1.10	456	502	6.8	7.1	50	66	YES
4/27/2025	9:00	1.12	550	619	6.7	7.1	50	54	YES
4/28/2025	18:00	1.15	465	537	6.6	7.1	51	65	YES
4/29/2025	3:00	0.98	561	551	6.8	7.1	49	53	YES
4/30/2025	16:00	0.94	454	425	6.8	7.1	49	66	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

5-May-24

CERT # 3675