

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Feb-26

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
2/1/2026	10:00	1.01	1363	1377	5.1	7.2	58	22	YES
2/2/2026	12:00	1.10	427	470	5.2	7.5	65	70	YES
2/3/2026	18:00	1.35	502	675	5.3	7.2	59	60	YES
2/4/2026	16:00	1.22	515	628	5.6	7.2	57	58	YES
2/5/2026	16:00	1.14	466	533	5.7	7.2	56	64	YES
2/6/2026	15:00	1.12	491	549	5.9	7.2	55	61	YES
2/7/2026	15:00	1.08	480	519	5.9	7.2	55	63	YES
2/8/2026	10:00	0.92	462	425	5.9	7.2	54	65	YES
2/9/2026	19:00	0.80	456	366	5.7	7.2	54	66	YES
2/10/2026	17:00	0.82	493	402	5.2	7.3	57	61	YES
2/11/2026	14:00	0.92	471	433	4.9	7.2	58	64	YES
2/12/2026	9:00	1.00	479	478	4.9	7.2	59	63	YES
2/13/2026	18:00	1.04	482	503	5.0	7.6	66	62	YES
2/14/2026	19:00	1.49	408	607	5.1	7.3	63	74	YES
2/15/2026	10:00	1.32	423	559	5.2	7.3	61	71	YES
2/16/2026	18:00	1.21	411	498	4.7	7.3	62	73	YES
2/17/2026	12:00	1.09	466	510	4.1	7.2	63	64	YES
2/18/2026	8:00	1.07	466	497	3.8	7.2	64	64	YES
2/19/2026	18:00	1.05	470	493	3.8	7.3	64	64	YES
2/20/2026	18:00	0.89	471	419	3.7	7.3	64	64	YES
2/21/2026	10:00	0.89	446	399	3.6	7.3	65	67	YES
2/22/2026	17:00	1.08	449	487	3.8	7.3	65	67	YES
2/23/2026	12:00	0.97	469	456	4.1	7.3	63	64	YES
2/24/2026	11:00	0.76	463	350	4.2	7.2	60	65	YES
2/25/2026	18:00	0.75	464	349	4.6	7.2	58	65	YES
2/26/2026	13:00	0.86	514	443	4.6	7.5	66	58	YES
2/27/2026	9:00	1.36	478	650	4.3	7.3	65	63	YES
2/28/2026	8:00	1.21	458	553	4.3	7.3	64	66	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 2-Mar-26 CERT # 3675