

OHA - Drinking Water Program - Turbidity Monitoring Report form County  
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Mar-21

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.62	0.62	0.62	0.055	0.055	0.055	0.62
2	0.055	0.055			0.055	0.055	0.055
3	0.055	0.055	0.055			0.055	0.055
4	0.055	0.055	0.055		0.055	0.055	0.055
5	0.055	0.055	0.055	0.055	0.055	0.055	0.055
6	0.055	0.055	0.055	0.062	0.062	0.055	0.062
7	0.062	0.062	0.062	0.062	0.062	0.062	0.062
8			0.055	0.055	0.055	0.055	0.055
9					0.055		0.055
10	0.082	0.082	0.082				0.082
11							0
12							0
13					0.062		0.062
14							0
15							0
16							0
17							0
18					0.062	0.062	0.062
19							0
20					0.075		0.075
21							0
22							0
23		0.075	0.075	0.075			0.075
24							0
25	0.075	0.075					0.075
26	0.075	0.075					0.075
27							0
28							0
29			0.055	0.055	0.055	0.055	0.055
30	0.055	0.055	0.055	0.055			0.055
31					0.055		0.055

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702  
 SURFACE WATER QUALITY DATA

Mar-21

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
3/1/2021	19:00	0.62	343	212	3.3	8.3	93	87	YES
3/2/2021	18:00	1.37	335	461	3.4	8.0	90	89	YES
3/3/2021	19:00	1.50	344	515	3.4	8.0	90	87	YES
3/4/2021	7:00	1.51	350	528	3.5	8.0	90	86	YES
3/5/2021	9:00	1.50	331	496	3.7	8.0	90	91	YES
3/6/2021	11:00	1.50	307	460	3.7	8.0	90	98	YES
3/7/2021	9:00	1.48	292	431	3.7	8.0	90	103	YES
3/8/2021	7:00	1.40	337	471	3.7	8.0	89	89	YES
3/9/2021	10:00	1.46	409	595	3.7	8.0	88	73	YES
3/10/2021	16:00	1.87	440	821	3.8	7.7	84	68	YES
3/11/2021	19:00	1.68	444	744	3.8	7.7	82	68	YES
3/12/2021	18:00	1.56	433	674	3.8	7.7	79	69	YES
3/13/2021	12:00	1.45	366	530	3.8	7.9	86	82	YES
3/14/2021	17:00	1.41	417	586	3.9	7.6	75	72	YES
3/15/2021	17:00	0.88	432	380	3.7	7.6	71	69	YES
3/16/2021	20:00	0.75	446	333	3.6	7.6	71	67	YES
3/17/2021	8:00	0.70	442	307	3.5	7.5	69	68	YES
3/18/2021	19:00	0.69	422	289	3.6	7.7	72	71	YES
3/19/2021	21:00	0.43	456	197	3.8	7.7	69	66	YES
3/20/2021	12:00	0.61	386	234	4.0	7.7	70	78	YES
3/21/2021	8:00	0.61	415	252	3.8	7.6	70	72	YES
3/22/2021	8:00	0.59	415	243	3.8	7.6	70	72	YES
3/23/2021	11:00	0.43	348	149	3.8	7.7	71	86	YES
3/24/2021	20:00	0.54	446	241	3.8	7.7	71	67	YES
3/25/2021	9:00	0.55	426	236	4.0	7.6	69	70	YES
3/26/2021	12:00	0.56	400	225	4.0	7.7	71	75	YES
3/27/2021	12:00	0.63	402	252	4.2	7.7	70	75	YES
3/28/2021	16:00	0.66	403	266	4.3	7.7	71	75	YES
3/29/2021	4:00	0.62	472	292	3.8	7.7	71	64	YES
3/30/2021	20:00	0.62	772	481	4.0	7.6	69	39	YES
3/31/2021	15:00	0.35	554	191	4.0	7.5	64	54	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262  
 SIGNATURE: David Jacob  
 PRINT NAME: David Jacob

DATE: 4-Apr-21 CERT # 3675