

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Apr-21

DAY	Cartridge Turbidity null values = system off A2						WPT	HIGHEST READING NTU
	12-4	4-8	8-12	12-16	16-20	20-24		
1								0.000
2								0.000
3					0.07			0.070
4								0.000
5						0.077		0.077
6					0.07	0.07		0.070
7					0.077	0.07		0.077
8					0.07	0.07		0.070
9						0.07		0.070
10					0.07	0.07		0.070
11								0.000
12								0.000
13								0.000
14								0.000
15					0.07			0.070
16					0.077	0.07		0.077
17				0.07	0.07	0.07		0.070
18	0.077	0.077	0.077					0.077
19								0.000
20								0.000
21								0.000
22								0.000
23								0.000
24								0.000
25								0.000
26								0.000
27								0.000
28						0.07		0.070
29								0.000
30								0.000



OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Apr-21

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
4/1/2021	18:00	0.63	432	270	4.2	7.5	65	70	YES
4/2/2021	11:00	0.67	439	293	4.5	7.5	63	68	YES
4/3/2021	9:00	0.65	399	261	4.7	7.6	66	75	YES
4/4/2021	9:00	0.65	418	272	4.9	7.5	62	72	YES
4/5/2021	8:00	0.66	418	275	4.6	7.5	64	72	YES
4/6/2021	9:00	0.67	415	277	4.6	7.6	66	72	YES
4/7/2021	12:00	0.67	434	291	4.6	7.5	64	69	YES
4/8/2021	20:00	0.66	416	275	4.6	7.6	66	72	YES
4/9/2021	11:00	0.65	407	263	4.3	7.6	68	74	YES
4/10/2021	17:00	0.66	412	273	4.3	7.5	65	73	YES
4/11/2021	13:00	0.64	397	253	4.1	7.6	67	76	YES
4/12/2021	13:00	0.70	429	299	4.2	7.6	69	70	YES
4/13/2021	17:00	0.67	429	287	4.2	7.5	66	70	YES
4/14/2021	17:00	0.67	446	299	4.2	7.6	68	67	YES
4/15/2021	15:00	0.69	412	285	4.5	7.6	67	73	YES
4/16/2021	17:00	0.70	414	288	4.8	7.6	65	72	YES
4/17/2021	9:00	0.68	398	270	5.1	7.7	66	75	YES
4/18/2021	15:00	0.65	375	243	5.4	7.7	64	80	YES
4/19/2021	12:00	0.64	310	197	5.7	7.7	62	97	YES
4/20/2021	11:00	0.63	431	271	5.8	7.5	59	70	YES
4/21/2021	0:00	0.67	431	290	5.8	7.5	60	70	YES
4/22/2021	20:00	0.66	511	335	5.8	7.5	59	59	YES
4/23/2021	0:00	0.66	436	287	5.9	7.6	59	69	YES
4/24/2021	15:00	0.66	509	336	5.9	7.5	59	59	YES
4/25/2021	12:00	0.67	411	277	5.9	7.5	58	73	YES
4/26/2021	13:00	0.65	469	307	5.9	7.5	58	64	YES
4/27/2021	0:00	0.60	437	260	5.9	7.5	59	69	YES
4/28/2021	11:00	0.58	517	300	5.9	7.6	59	58	YES
4/29/2021	7:00	0.61	410	251	6.2	7.6	58	73	YES
4/30/2021	12:00	0.63	373	234	6.5	7.6	57	80	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 5-May-21 CERT # 3675