

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Jun-21

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.077	0.077	0.077	0.077	0.077	0.077	0.077
2	0.077	0.084	0.077	0.077	0.077	0.077	0.084
3	0.077	0.077	0.077	0.077	0.077	0.077	0.077
4	0.084	0.077	0.077	0.077	0.077	0.077	0.084
5						0.077	0.077
6				0.077		0.077	0.077
7				0.077		0.077	0.077
8						0.077	0.077
9	0.077	0.077					0.077
10							0
11							0
12							0
13				0.077	0.077		0.077
14							0
15				0.089	0.095		0.095
16							0
17				0.088	0.088		0.088
18							0
19				0.085	0.085	0.085	0.085
20		0.092	0.085		0.099		0.099
21	0.092		0.092	0.085	0.085	0.085	0.092
22							0
23		0.085	0.085	0.085	0.085		0.085
24	0.085	0.085		0.093	0.092	0.085	0.093
25	0.085	0.085	0.085	0.093	0.099	0.083	0.099
26	0.085	0.085	0.085	0.093	0.099	0.083	0.099
27		0.099	0.099	0.099	0.099	0.083	0.099
28	0.091	0.091	0.099	0.099	0.091	0.091	0.099
29	0.091	0.091	0.091	0.099	0.091	0.091	0.099
30		0.099	0.085	0.099	0.091	0.091	0.099

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Jun-21

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
6/1/2021	5:00	0.91	447	408	8.6	7.7	53	67	YES
6/2/2021	15:00	0.86	311	269	9.2	7.7	51	96	YES
6/3/2021	10:00	0.84	404	338	9.5	7.6	49	74	YES
6/4/2021	15:00	0.73	316	229	8.9	7.5	49	95	YES
6/5/2021	17:00	0.52	385	200	8.5	7.5	48	78	YES
6/6/2021	9:00	0.45	368	167	7.7	7.5	50	82	YES
6/7/2021	11:00	0.42	256	109	7.5	7.5	51	117	YES
6/8/2021	8:00	0.45	405	182	8.1	7.5	48	74	YES
6/9/2021	15:00	0.39	353	136	7.4	7.5	51	85	YES
6/10/2021	6:00	0.37	448	165	8.2	7.5	48	67	YES
6/11/2021	18:00	0.38	401	151	8.2	7.5	48	75	YES
6/12/2021	19:00	0.45	440	200	8.4	7.5	48	68	YES
6/13/2021	9:00	0.44	358	157	8.6	7.5	47	84	YES
6/14/2021	3:00	0.41	462	191	9.0	7.4	45	65	YES
6/15/2021	20:00	0.40	391	156	9.2	7.5	45	77	YES
6/16/2021	11:00	0.39	460	179	9.1	7.5	45	65	YES
6/17/2021	12:00	0.41	367	150	9.2	7.5	46	82	YES
6/18/2021	19:00	0.42	435	185	9.6	7.5	44	69	YES
6/19/2021	13:00	0.43	316	135	9.3	7.6	46	95	YES
6/20/2021	18:00	0.45	329	147	9.8	7.6	45	91	YES
6/21/2021	18:00	0.46	233	106	10.2	7.6	45	129	YES
6/22/2021	9:00	0.41	336	138	10.9	7.6	41	89	YES
6/23/2021	9:00	0.38	337	129	10.7	7.5	41	89	YES
6/24/2021	10:00	0.38	353	133	11.1	7.5	40	85	YES
6/25/2021	19:00	0.38	326	124	11.2	7.6	41	92	YES
6/26/2021	9:00	0.36	316	115	11.8	7.6	39	95	YES
6/27/2021	10:00	0.37	306	114	12.2	7.6	39	98	YES
6/28/2021	18:00	0.36	326	118	12.8	7.6	37	92	YES
6/29/2021	8:00	0.37	316	118	12.7	7.7	38	95	YES
6/30/2021	17:00	0.36	333	121	11.8	7.6	40	90	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 7/6/2021 CERT # 3675