

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Jul-21

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.099	0.084	0.092	0.092	0.092	0.092	0.099
2		0.099	0.099	0.099	0.099	0.099	0.099
3	0.099	0.099	0.099	0.099	0.099	0.106	0.106
4	0.106		0.099	0.099	0.099	0.099	0.106
5			0.106	0.099	0.099	0.099	0.106
6	0.099			0.106	0.106	0.106	0.106
7		0.106	0.106	0.106	0.106		0.106
8				0.106			0.106
9			0.106	0.106	0.106		0.106
10			0.106	0.106	0.106		0.106
11			0.106	0.106	0.114	0.114	0.114
12	0.114		0.106	0.106	0.106	0.106	0.114
13	0.106		0.106	0.106	0.106	0.106	0.106
14	0.106	0.106	0.106	0.106	0.106	0.106	0.106
15	0.106			0.106	0.106		0.106
16			0.106	0.106	0.106		0.106
17	0.099	0.099	0.099	0.099	0.099	0.099	0.099
18	0.099	0.099	0.099	0.099	0.099	0.099	0.099
19	0.099	0.099	0.099	0.099	0.099	0.099	0.099
20	0.099	0.099	0.099	0.084	0.099	0.099	0.099
21	0.099	0.099	0.099	0.099	0.099	0.084	0.099
22	0.077	0.077	0.077	0.077	0.077	0.077	0.077
23	0.077	0.077	0.077	0.077	0.077	0.077	0.077
24	0.077	0.077	0.077	0.077	0.077	0.077	0.077
25	0.07	0.07	0.07	0.07	0.07	0.07	0.07
26	0.07	0.07	0.07	0.07	0.07	0.84	0.84
27	0.07	0.07	0.07	0.07	0.07	0.07	0.07
28	0.07	0.07	0.07	0.07	0.07	0.07	0.07
29	0.063	0.063	0.063	0.063	0.063	0.063	0.063
30	0.063	0.7	0.063	0.063	0.063	0.063	0.7
31		0.063	0.063	0.063	0.063	0.063	0.063

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Jul-21

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
7/1/2021	16:00	0.40	323	130	11.4	7.6	41	93	YES
7/2/2021	17:00	0.42	289	122	11.1	7.8	44	104	YES
7/3/2021	16:00	0.91	250	227	11.1	7.7	45	120	YES
7/4/2021	12:00	0.86	258	222	11.1	7.7	45	116	YES
7/5/2021	11:00	0.82	273	223	10.8	7.6	45	110	YES
7/6/2021	17:00	0.86	258	221	10.4	7.7	47	116	YES
7/7/2021	11:00	0.87	323	282	10.9	7.7	46	93	YES
7/8/2021	18:00	0.86	307	262	10.7	7.7	46	98	YES
7/9/2021	20:00	0.87	296	258	10.2	7.7	48	101	YES
7/10/2021	10:00	0.84	284	239	10.9	7.7	46	106	YES
7/11/2021	16:00	0.87	234	204	10.6	7.7	47	128	YES
7/12/2021	17:00	0.86	302	259	10.8	7.7	47	99	YES
7/13/2021	10:00	1.07	297	317	10.7	7.8	48	101	YES
7/14/2021	12:00	1.08	305	330	10.8	7.8	48	98	YES
7/15/2021	14:00	1.07	280	299	10.8	7.8	48	107	YES
7/16/2021	17:00	1.04	309	320	10.0	7.8	51	97	YES
7/17/2021	17:00	1.01	283	286	10.0	7.8	51	106	YES
7/18/2021	18:00	0.99	276	273	10.3	7.8	50	109	YES
7/19/2021	16:00	0.97	291	282	10.3	7.8	49	103	YES
7/20/2021	17:00	0.96	291	279	10.4	7.8	49	103	YES
7/21/2021	19:00	0.95	303	289	9.7	7.7	51	99	YES
7/22/2021	15:00	0.97	244	236	9.2	7.8	53	123	YES
7/23/2021	13:00	0.52	204	106	9.5	7.7	49	147	YES
7/24/2021	15:00	0.50	228	115	10.0	7.7	46	132	YES
7/25/2021	17:00	0.45	200	90	10.7	7.7	44	150	YES
7/26/2021	20:00	0.44	281	122	10.8	7.7	44	107	YES
7/27/2021	17:00	0.42	269	112	11.0	7.7	43	111	YES
7/28/2021	10:00	0.41	296	122	10.7	7.7	44	101	YES
7/29/2021	21:00	0.42	307	128	11.1	7.7	43	98	YES
7/30/2021	15:00	0.41	262	109	11.6	7.7	41	114	YES
7/31/2021	16:00	0.41	269	110	12.2	7.6	39	111	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME: David Jacob

DATE: 4-Aug-21 CERT # 3675