

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Aug-21

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.062	0.062	0.062	0.062	0.062	0.062	0.062
2		0.062	0.055	0.062	0.062	0.062	0.062
3	0.055	0.055	0.055	0.055	0.055	0.055	0.055
4	0.062	0.062	0.062	0.062	0.062	0.062	0.062
5				0.07	0.062	0.055	0.07
6	0.055	0.055	0.055				0.055
7				0.055	0.055	0.055	0.055
8	0.055		0.055				0.055
9						0.055	0.055
10					0.048	0.048	0.048
11	0.048			0.048			0.048
12			0.048	0.048	0.055	0.062	0.062
13				0.055	0.055	0.055	0.055
14	0.055	0.048	0.04	0.048	0.055	0.055	0.055
15	0.048	0.048	0.048	0.048	0.048	0.048	0.048
16	0.048	0.048	0.048	0.048	0.048	0.048	0.048
17							0
18				0.048	0.048	0.048	0.048
19					0.048	0.048	0.048
20	0.048	0.048	0.048	0.048	0.048	0.048	0.048
21	0	0.048	0.04	0.04	0.04	0.04	0.048
22	0.04	0.04	0.04	0.04	0.04	0.04	0.04
23	0.04	0.04	0.04	0.04	0.04	0.04	0.04
24	0.04	0.04	0.04	0.04	0.04	0.04	0.04
25	0.04	0.04	0.04	0.04	0.04	0.04	0.04
26	0.04	0.04	0.04	0.04	0.04	0.04	0.04
27	0.04	0.04	0.04	0.04	0.04	0.04	0.04
28	0.04	0.04	0.04	0.04	0.04	0.04	0.04
29	0.04	0.04	0.04	0.04	0.04	0.04	0.04
30							0
31				0.04	0.04	0.04	0.04

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Aug-21

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
8/1/2021	18:00	0.41	235	95	11.9	7.7	41	128	YES
8/2/2021	16:00	0.42	262	110	12.0	7.8	41	114	YES
8/3/2021	17:00	0.42	263	111	12.2	7.7	40	114	YES
8/4/2021	13:00	0.40	277	111	11.8	7.7	41	108	YES
8/5/2021	19:00	0.40	297	118	11.9	7.7	40	101	YES
8/6/2021	9:00	0.40	305	122	11.3	7.7	42	98	YES
8/7/2021	16:00	0.37	265	97	11.5	7.7	42	113	YES
8/8/2021	10:00	0.32	295	94	10.7	7.7	44	102	YES
8/9/2021	16:00	0.36	335	120	10.9	7.7	43	90	YES
8/10/2021	18:00	0.51	285	144	10.8	7.7	45	105	YES
8/11/2021	18:00	0.59	276	164	11.8	7.7	42	109	YES
8/12/2021	14:00	0.62	191	118	12.5	7.7	40	157	YES
8/13/2021	18:00	0.35	205	72	13.0	8.0	41	146	YES
8/14/2021	14:00	0.92	192	175	12.7	7.7	41	157	YES
8/15/2021	16:00	0.91	251	228	12.3	7.7	42	120	YES
8/16/2021	10:00	0.88	224	198	12.0	7.8	43	134	YES
8/17/2021	17:00	0.85	406	344	12.3	7.7	41	74	YES
8/18/2021	19:00	0.81	335	272	10.4	7.8	48	90	YES
8/19/2021	17:00	0.81	363	293	10.8	7.8	47	83	YES
8/20/2021	8:00	0.74	253	186	10.3	7.8	48	119	YES
8/21/2021	16:00	0.72	380	275	10.1	7.7	48	79	YES
8/22/2021	9:00	0.71	337	241	9.7	7.7	49	89	YES
8/23/2021	9:00	0.72	293	212	8.7	7.8	54	102	YES
8/24/2021	20:00	0.95	314	297	8.5	7.8	55	96	YES
8/25/2021	8:00	0.89	326	288	9.1	7.8	53	92	YES
8/26/2021	12:00	0.82	298	245	9.6	7.7	50	101	YES
8/27/2021	13:00	0.79	307	242	9.8	7.7	50	98	YES
8/28/2021	17:00	0.79	261	207	9.0	7.8	52	115	YES
8/29/2021	16:00	0.80	202	161	9.8	7.7	49	149	YES
8/30/2021	18:00	0.82	393	322	10.6	7.6	45	76	YES
8/31/2021	13:00	0.80	336	269	9.3	7.7	51	89	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME: David Jacob

DATE: 9/3/2021 CERT # 3675