

OHA - Drinking Water Program - Turbidity Monitoring Report form County  
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Nov-21

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1			0.158			0.158	0.158
2	0.158	0.158	0.158	0.158	0.158		0.158
3	0.158		0.144	0.144	0.144	0.144	0.158
4	0.136	0.136	0.136	0.136	0.136	0.136	0.136
5	0.136			0.136	0.128	0.128	0.136
6	0.128	0.128	0.128	0.128	0.128	0.128	0.128
7	0.114	0.114	0.114	0.114	0.114	0.114	0.114
8	0.114	0.114	0.114	0.114	0.114	0.114	0.114
9	0.114	0.114					0.114
10				0.114	0.108	0.108	0.114
11	0.108	0.108					0.108
12					0.128	0.128	0.128
13	0.099	0.099	0.099	0.099		0.099	0.099
14	0.099	0.099			0.099		0.099
15					0.099	0.099	0.099
16	0.099	0.099					0.099
17	0.084	0.084					0.084
18					0.084	0.084	0.084
19	0.084	0.084	0.084				0.084
20					0.077	0.077	0.077
21	0.077	0.077	0.077	0.077	0.077		0.077
22					0.077	0.077	0.077
23	0.077	0.077	0.077	0.077	0.077		0.077
24						0.077	0.077
25	0.077	0.077	0.077	0.077	0.077	0.077	0.077
26	0.077	0.077			0.077	0.077	0.077
27	0.077	0.077	0.077	0.084	0.084		0.084
28					0.077	0.077	0.077
29	0.077	0.077			0.077		0.077
30					0.077	0.077	0.077
31							

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702  
 SURFACE WATER QUALITY DATA

Nov-21

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
11/1/2021	20:00	1.01	433	435	6.3	7.6	61	69	YES
11/2/2021	9:00	1.03	443	456	6.5	7.7	63	68	YES
11/3/2021	20:00	1.05	443	463	7.1	7.8	61	68	YES
11/4/2021	10:00	1.09	429	469	7.4	7.7	60	70	YES
11/5/2021	22:00	1.04	504	522	7.0	7.9	66	60	YES
11/6/2021	11:00	1.23	367	453	6.2	7.7	65	82	YES
11/7/2021	9:00	1.17	437	509	5.7	7.7	67	69	YES
11/8/2021	10:00	1.20	446	533	5.5	7.8	70	67	YES
11/9/2021	18:00	1.20	569	681	5.8	7.7	68	53	YES
11/10/2021	20:00	1.16	451	525	5.9	7.8	68	67	YES
11/11/2021	0:00	1.12	515	578	6.3	7.8	67	58	YES
11/12/2021	11:00	0.62	434	267	7.1	7.9	61	69	YES
11/13/2021	23:00	0.44	499	217	7.7	7.9	58	60	YES
11/14/2021	10:00	0.55	386	211	8.0	7.9	58	78	YES
11/15/2021	23:00	0.92	495	454	8.2	7.8	58	61	YES
11/16/2021	15:00	1.06	450	477	6.4	7.7	63	67	YES
11/17/2021	23:00	1.36	523	710	5.9	7.6	65	57	YES
11/18/2021	16:00	1.39	452	628	6.4	7.7	65	66	YES
11/19/2021	5:00	1.28	509	651	6.7	7.7	64	59	YES
11/20/2021	17:00	1.23	425	521	6.0	7.7	65	71	YES
11/21/2021	10:00	1.33	461	611	5.6	7.7	69	65	YES
11/22/2021	16:00	1.35	427	577	6.0	7.7	68	70	YES
11/23/2021	6:00	1.41	482	681	6.1	7.7	68	62	YES
11/24/2021	19:00	1.37	430	588	5.4	7.7	70	70	YES
11/25/2021	7:00	1.33	479	636	5.4	7.7	71	63	YES
11/26/2021	15:00	1.35	402	543	5.8	8.1	78	75	YES
11/27/2021	10:00	1.54	457	706	6.2	7.8	70	66	YES
11/28/2021	13:00	1.40	440	615	6.6	7.8	67	68	YES
11/29/2021	23:00	1.34	502	671	6.9	7.8	65	60	YES
11/30/2021	20:00	1.29	455	589	7.1	7.8	63	66	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262  
 SIGNATURE: David Jacob  
 PRINT NAME: David Jacob

DATE: 3-Dec CERT # 3675