

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Jan-22

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
1/1/2022	10:00	1.00	346	347	1.6	7.7	88	87	YES
1/2/2022	10:00	1.02	427	435	2.3	7.8	86	70	YES
1/3/2022	10:00	1.02	286	293	2.6	7.8	83	105	YES
1/4/2022	23:00	0.98	435	425	2.8	7.7	81	69	YES
1/5/2022	8:00	0.97	390	377	2.9	7.8	81	77	YES
1/6/2022	22:00	0.80	429	342	2.9	7.9	83	70	YES
1/7/2022	8:00	0.75	384	288	3.3	8.3	94	78	YES
1/8/2022	21:00	0.89	342	304	3.6	7.7	74	88	YES
1/9/2022	9:00	0.76	336	256	3.7	7.7	72	89	YES
1/10/2022	22:00	0.74	423	311	3.8	7.6	71	71	YES
1/11/2022	11:00	0.78	368	286	3.8	7.6	71	82	YES
1/12/2022	18:00	0.74	448	333	3.9	7.6	70	67	YES
1/13/2022	13:00	0.71	375	266	3.9	7.6	69	80	YES
1/14/2022	19:00	0.72	420	304	4.0	7.6	69	72	YES
1/15/2022	12:00	0.73	352	256	3.9	7.6	68	85	YES
1/16/2022	17:00	0.70	415	289	3.9	7.5	68	72	YES
1/17/2022	9:00	0.68	358	244	3.9	7.5	68	84	YES
1/18/2022	16:00	0.68	445	304	3.9	7.5	67	67	YES
1/19/2022	12:00	0.55	391	215	4.0	7.4	64	77	YES
1/20/2022	0:00	0.47	454	211	4.1	7.5	64	66	YES
1/21/2022	21:00	0.44	415	182	4.2	8.0	77	72	YES
1/22/2022	17:00	0.73	449	326	4.1	7.5	67	67	YES
1/23/2022	11:00	0.70	384	270	4.1	7.6	68	78	YES
1/24/2022	1:00	0.70	469	329	4.0	7.6	68	64	YES
1/25/2022	14:00	0.74	428	316	4.0	7.6	68	70	YES
1/26/2022	6:00	0.72	496	358	3.8	7.6	71	61	YES
1/27/2022	18:00	0.72	403	291	3.8	7.6	71	74	YES
1/28/2022	10:00	0.74	412	304	3.7	7.6	71	73	YES
1/29/2022	10:00	0.76	447	338	3.6	7.6	70	67	YES
1/30/2022	12:00	0.75	458	345	3.6	7.6	71	66	YES
1/31/2022	19:00	0.75	418	314	3.6	7.6	70	72	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 4-Feb-22 CERT # 3675