

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Mar-22

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.114	0.099	0.099	0.114	0.099	0.114	0.114
2	0.099	0.099	0.106	0.114	0.099	0.106	0.114
3	0.099	0.114	0.099				0.114
4	0.099	0.099	0.099	0.099	0.099	0.099	0.099
5	0.106	0.114	0.114	0.106	0.099	0.114	0.114
6	0.099	0.099	0.099	0.099	0.106	0.099	0.106
7	0.099	0.099	0.099			0.114	0.114
8		0.114	0.114	0.114	0.114	0.114	0.114
9	0.114	0.114	0.114	0.114	0.114	0.114	0.114
10	0.114	0.114	0.114	0.114	0.114	0.114	0.114
11	0.114	0.114	0.114	0.114	0.114	0.114	0.114
12	0.114	0.114	0.114	0.114	0.114	0.114	0.114
13	0.114		0.114	0.114	0.114	0.114	0.114
14		0.114	0.114	0.114	0.114	0.114	0.114
15	0.114	0.114	0.114	0.114	0.114		0.114
16		0.128	0.128	0.128	0.128	0.128	0.128
17	0.128	0.128	0.128	0.128	0.128	0.128	0.128
18	0.114		0.114	0.114	0.114	0.114	0.114
19	0.114	0.114	0.114	0.114	0.114	0.114	0.114
20	0.114	0.114	0.114	0.114	0.114		0.114
21		0.114	0.114	0.114	0.114	0.114	0.114
22	0.114	0.114	0.114	0.114	0.114	0.114	0.114
23	0.114	0.114	0.114	0.114	0.114	0.114	0.114
24	0.114	0.114	0.114	0.114	0.114	0.114	0.114
25	0.128	0.128	0.128	0.128	0.128	0.128	0.128
26	0.128	0.128	0.128	0.128	0.128	0.128	0.128
27	0.128	0.128	0.128	0.128	0.128	0.128	0.128
28	0.128	0.128	0.128	0.128	0.128	0.128	0.128
29	0.128	0.114	0.128	0.128	0.114	0.128	0.128
30	0.128	0.128	0.128	0.128	0.114	0.128	0.128
31	0.128	0.128	0.128	0.114	0.128	0.128	0.128

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Mar-22

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
3/1/2022	19:00	0.37	423	155	3.5	7.7	70	71	YES
3/2/2022	8:00	0.38	421	158	4.0	7.6	66	71	YES
3/3/2022	20:00	0.38	423	160	4.3	7.6	65	71	YES
3/4/2022	9:00	0.45	393	177	4.2	7.6	66	76	YES
3/5/2022	21:00	0.50	408	203	4.2	7.5	65	74	YES
3/6/2022	15:00	0.53	377	199	4.2	7.5	65	80	YES
3/7/2022	10:00	0.57	482	277	4.2	7.8	72	62	YES
3/8/2022	8:00	0.75	387	291	4.3	7.6	67	78	YES
3/9/2022	14:00	0.72	498	356	4.1	7.5	67	60	YES
3/10/2022	13:00	0.69	396	273	3.2	7.5	71	76	YES
3/11/2022	18:00	0.72	477	343	3.7	7.6	71	63	YES
3/12/2022	9:00	0.74	367	271	3.7	7.6	71	82	YES
3/13/2022	10:00	0.68	453	308	4.0	7.6	68	66	YES
3/14/2022	9:00	0.60	381	227	4.1	7.6	67	79	YES
3/15/2022	1:00	0.61	489	297	4.3	7.6	68	61	YES
3/16/2022	17:00	0.59	384	227	4.6	7.6	65	78	YES
3/17/2022	7:00	0.61	434	264	4.5	7.6	66	69	YES
3/18/2022	19:00	0.62	387	240	4.6	7.6	66	78	YES
3/19/2022	9:00	0.65	396	256	4.7	7.6	65	76	YES
3/20/2022	10:00	0.62	383	236	4.6	7.6	65	78	YES
3/21/2022	9:00	0.60	371	224	4.6	7.6	66	81	YES
3/22/2022	8:00	0.58	503	294	4.7	7.6	64	60	YES
3/23/2022	10:00	0.57	605	345	5.4	7.5	60	50	YES
3/24/2022	11:00	0.59	391	231	5.5	7.6	61	77	YES
3/25/2022	10:00	0.62	385	239	5.4	7.6	62	78	YES
3/26/2022	17:00	0.64	386	247	5.5	7.6	62	78	YES
3/27/2022	10:00	0.67	392	263	5.7	7.6	62	77	YES
3/28/2022	14:00	0.68	421	285	5.9	7.6	60	71	YES
3/29/2022	10:00	0.67	422	284	5.9	7.6	60	71	YES
3/30/2022	22:00	0.69	491	337	5.8	7.5	58	61	YES
3/31/2022	17:00	0.68	405	274	5.1	7.8	69	74	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME: David Jacob

DATE: 7-Apr-22 CERT # 3675