

OHA - Drinking Water Program - Turbidity Monitoring Report form County  
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Aug-22

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.068	0.094	0.062	0.064	0.062	0.058	0.094
2	0.061	0.061	0.062	0.036	0.036	0.035	0.062
3	0.037	0.036	0.036	0.035	0.036	0.037	0.037
4			0.038	0.038	0.038	0.036	0.038
5	0.039	0.04	0.038	0.036	0.035	0.036	0.04
6	0.037	0.039	0.037	0.035	0.035	0.035	0.039
7	0.036	0.032	0.035	0.033	0.032	0.034	0.036
8	0.031	0.032	0.033	0.032	0.03	0.032	0.033
9	0.033	0.032	0.032	0.033	0.029	0.032	0.033
10			0.032	0.034	0.03	0.033	0.034
11	0.032	0.03		0.031	0.034	0.033	0.034
12	0.032	0.032		0.03	0.032	0.032	0.032
13	0.029	0.033		0.03	0.031	0.031	0.033
14	0.032	0.039	0.039	0.037	0.033	0.036	0.039
15	0.036	0.038	0.036	0.035	0.033	0.038	0.038
16	0.036	0.035	0.034	0.035	0.034	0.035	0.036
17	0.036	0.036	0.038	0.036	0.036	0.035	0.038
18	0.035	0.034	0.037	0.036	0.036	0.035	0.037
19	0.036	0.037	0.034	0.037	0.036	0.035	0.037
20	0.035	0.034	0.035	0.032	0.036	0.039	0.039
21	0.037	0.031	0.035	0.032	0.036	0.032	0.037
22	0.034	0.032	0.031	0.033	0.03	0.033	0.034
23		0.035	0.035	0.034	0.035	0.036	0.036
24	0.037	0.036	0.036	0.041	0.037	0.037	0.041
25	0.034	0.035	0.038	0.036	0.036	0.035	0.038
26	0.035	0.036	0.037	0.036	0.035	0.035	0.037
27	0.036	0.035	0.038	0.035	0.035	0.036	0.038
28	0.033	0.035	0.035	0.039	0.035	0.037	0.039
29	0.035	0.04	0.037	0.037	0.036	0.041	0.041
30	0.039	0.037	0.039	0.039	0.037	0.036	0.039
31	0.036	0.035	0.038	0.036	0.036	0.034	0.038

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702  
 SURFACE WATER QUALITY DATA

Aug-22

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
8/1/2022	9:00	0.81	331	269	12.1	7.7	41	91	YES
8/2/2022	14:00	0.76	333	252	11.7	7.7	43	90	YES
8/3/2022	13:00	0.82	364	298	11.4	7.7	43	82	YES
8/4/2022	8:00	0.82	380	311	10.8	7.7	46	79	YES
8/5/2022	20:00	0.85	327	278	10.6	7.7	46	92	YES
8/6/2022	16:00	0.86	305	261	10.2	7.7	48	99	YES
8/7/2022	11:00	0.81	302	244	10.7	7.7	46	99	YES
8/8/2022	18:00	0.81	280	226	11.2	7.7	44	107	YES
8/9/2022	18:00	0.81	377	306	11.4	7.6	43	80	YES
8/10/2022	19:00	0.80	336	270	11.2	7.7	44	89	YES
8/11/2022	19:00	0.82	370	302	10.4	7.7	47	81	YES
8/12/2022	10:00	0.82	321	263	10.7	7.7	47	94	YES
8/13/2022	15:00	0.89	337	301	10.7	7.7	47	89	YES
8/14/2022	10:00	0.81	305	247	10.3	7.7	47	99	YES
8/15/2022	16:00	0.78	345	268	10.7	7.7	45	87	YES
8/16/2022	16:00	0.73	334	245	10.7	7.7	45	90	YES
8/17/2022	19:00	0.75	351	261	11.1	7.6	43	86	YES
8/18/2022	18:00	0.73	355	260	11.9	7.6	40	85	YES
8/19/2022	17:00	0.73	377	274	11.8	7.6	41	80	YES
8/20/2022	17:00	0.72	334	241	11.3	7.7	44	90	YES
8/21/2022	11:00	0.75	380	286	11.0	7.7	44	79	YES
8/22/2022	18:00	0.74	319	237	10.9	7.7	45	94	YES
8/23/2022	14:00	0.76	402	304	11.0	7.7	44	75	YES
8/24/2022	12:00	0.75	374	281	11.0	7.7	44	80	YES
8/25/2022	12:00	0.76	337	255	11.6	7.6	42	89	YES
8/26/2022	17:00	0.76	334	254	11.3	7.6	43	90	YES
8/27/2022	22:00	0.77	409	316	11.4	7.6	42	73	YES
8/28/2022	9:00	0.77	320	247	9.8	7.6	48	94	YES
8/29/2022	7:00	0.77	316	243	10.4	7.7	47	95	YES
8/30/2022	6:00	0.76	299	228	10.9	7.6	43	100	YES
8/31/2022	6:00	0.67	322	217	11.7	7.6	40	93	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262  
 SIGNATURE: David Jacob  
 PRINT NAME: David Jacob

DATE: 9/6/2022 CERT # 3675