

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Sep-22

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.036	0.037	0.037	0.036	0.038	0.034	0.038
2	0.039	0.038	0.036	0.037	0.034	0.035	0.039
3	0.036	0.036	0.036	0.036	0.036	0.034	0.036
4	0.036	0.035	0.036	0.035	0.036	0.035	0.036
5	0.041	0.04	0.037	0.038	0.04	0.036	0.041
6	0.036	0.036	0.036	0.035	0.036	0.036	0.036
7	0.037		0.038	0.036	0.036	0.037	0.038
8	0.038	0.038	0.039	0.035	0.038	0.037	0.039
9	0.037	0.039	0.038	0.036	0.04	0.039	0.04
10	0.037	0.04	0.036	0.037	0.038	0.035	0.04
11	0.038		0.038	0.038	0.038	0.04	0.04
12	0.039	0.038	0.037	0.036	0.032	0.035	0.039
13	0.04	0.04	0.039	0.039	0.04	0.04	0.04
14	0.035	0.038	0.037	0.034	0.034		0.038
15			0.038	0.039	0.036	0.037	0.039
16	0.037		0.038	0.038	0.035	0.039	0.039
17	0.039	0.038	0.039	0.037	0.037	0.037	0.039
18	0.034	0.034	0.036	0.035	0.038	0.037	0.038
19	0.036	0.037	0.037	0.037	0.037	0.037	0.037
20	0.038	0.039	0.037	0.039	0.036	0.037	0.039
21	0.038	0.039	0.038	0.042	0.038	0.037	0.042
22	0.038	0.042	0.04	0.039	0.037	0.037	0.042
23	0.039	0.036	0.037	0.036	0.037		0.039
24			0.034	0.037	0.036	0.038	0.038
25	0.042	0.039	0.04	0.043	0.04	0.04	0.043
26	0.037	0.039	0.038	0.036	0.037	0.037	0.039
27	0.038	0.038	0.04	0.04	0.039		0.04
28	0.04	0.039		0.04	0.04		0.04
29			0.038	0.037	0.038	0.039	0.039
30				0.04	0.038	0.04	0.04
31							0

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Sep-22

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
9/1/2022	6:00	0.65	366	238	11.2	7.6	42	82	YES
9/2/2022	17:00	0.64	526	336	11.2	7.7	44	57	YES
9/3/2022	19:00	0.63	475	300	10.9	7.7	44	63	YES
9/4/2022	10:00	0.63	497	314	10.0	7.7	47	60	YES
9/5/2022	9:00	0.63	432	272	10.6	7.7	45	70	YES
9/6/2022	6:00	0.64	403	256	10.4	7.7	45	75	YES
9/7/2022	18:00	0.63	505	320	10.7	7.7	45	59	YES
9/8/2022	22:00	0.61	557	337	9.7	7.7	48	54	YES
9/9/2022	11:00	0.62	390	242	9.8	7.7	48	77	YES
9/10/2022	15:00	0.63	414	263	9.8	7.7	47	72	YES
9/11/2022	11:00	0.62	413	257	10.2	7.6	45	73	YES
9/12/2022	16:00	0.62	796	490	10.8	7.6	43	38	YES
9/13/2022	7:00	0.61	1136	691	10.9	7.6	42	26	YES
9/14/2022	18:00	0.60	829	498	10.7	7.6	43	36	YES
9/15/2022	19:00	0.60	566	340	10.1	7.6	46	53	YES
9/16/2022	18:00	0.60	640	386	9.7	7.7	48	47	YES
9/17/2022	15:00	0.63	512	323	9.4	7.7	49	59	YES
9/18/2022	9:00	0.58	563	325	9.2	7.7	49	53	YES
9/19/2022	20:00	0.57	645	369	9.3	7.6	48	47	YES
9/20/2022	17:00	0.57	531	302	9.7	7.6	47	57	YES
9/21/2022	12:00	0.53	714	379	9.5	7.6	47	42	YES
9/22/2022	9:00	0.52	699	362	9.3	7.6	48	43	YES
9/23/2022	13:00	0.51	822	419	9.1	7.6	48	37	YES
9/24/2022	10:00	0.50	535	268	8.9	7.6	49	56	YES
9/25/2022	9:00	0.45	655	295	9.4	7.6	47	46	YES
9/26/2022	17:00	0.55	495	270	9.8	7.6	46	61	YES
9/27/2022	16:00	0.56	706	397	10.3	7.6	44	43	YES
9/28/2022	19:00	0.55	593	325	9.8	7.6	46	51	YES
9/29/2022	14:00	0.52	852	443	9.7	7.6	46	35	YES
9/30/2022	18:00	0.47	621	294	9.7	7.6	45	48	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 4-Oct-22 CERT # 3675