

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Oct-22

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.039	0.038	0.04	0.041	0.037	0.039	0.041
2	0.039	0.039	0.04				0.04
3	0.039	0.037	0.04	0.038	0.038	0.037	0.04
4						0.04	0.04
5	0.036	0.038	0.042	0.039	0.039	0.039	0.042
6	0.039				0.036	0.04	0.04
7	0.037	0.037	0.037	0.036	0.035	0.039	0.039
8	0.038	0.038			0.036	0.038	0.038
9	0.036	0.038	0.035	0.037	0.037	0.04	0.04
10			0.037	0.038	0.038	0.037	0.038
11	0.036	0.038	0.033	0.03	0.033		0.038
12		0.031	0.038	0.039	0.039	0.036	0.039
13	0.04	0.04	0.042	0.041	0.042	0.037	0.042
14	0.039	0.038	0.038	0.037			0.039
15	0.038	0.037	0.037	0.038	0.037	0.037	0.038
16			0.037	0.036	0.036	0.037	0.037
17	0.038	0.036		0.036	0.038	0.037	0.038
18	0.037	0.036	0.036	0.039	0.036	0.038	0.039
19							0
20							0
21							0
22	0.038					0.036	0.038
23	0.033	0.035	0.033	0.042	0.037		0.042
24		0.04	0.037	0.039	0.045		0.045
25			0.041	0.037	0.036	0.038	0.041
26	0.035	0.036	0.038				0.038
27			0.039	0.037	0.037	0.035	0.039
28	0.038	0.034	0.035	0.033			0.038
29	0.041	0.039	0.042	0.041	0.039	0.038	0.042
30	0.038	0.039	0.04	0.041	0.04	0.039	0.041
31	0.037	0.037	0.038			0.04	0.04

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Oct-22

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
10/1/2022	9:00	0.47	404	191	9.7	7.6	45	74	YES
10/2/2022	17:00	0.48	355	170	10.0	7.6	44	85	YES
10/3/2022	10:00	0.49	410	202	10.0	7.6	44	73	YES
10/4/2022	19:00	0.51	427	216	10.2	7.5	43	70	YES
10/5/2022	10:00	0.53	429	229	9.8	7.6	45	70	YES
10/6/2022	19:00	0.51	420	214	10.2	7.5	43	71	YES
10/7/2022	10:00	0.51	388	198	10.1	7.7	46	77	YES
10/8/2022	15:00	0.70	350	243	10.1	7.6	45	86	YES
10/9/2022	12:00	0.64	347	223	9.9	7.6	46	86	YES
10/10/2022	19:00	0.61	386	236	9.9	7.6	46	78	YES
10/11/2022	7:00	0.60	401	241	9.7	7.6	47	75	YES
10/12/2022	15:00	0.59	414	244	9.3	7.6	47	72	YES
10/13/2022	8:00	0.58	434	251	9.4	7.6	47	69	YES
10/14/2022	19:00	0.58	399	230	9.6	7.6	46	75	YES
10/15/2022	10:00	0.58	324	189	9.3	7.6	48	93	YES
10/16/2022	19:00	0.57	418	239	9.7	7.6	46	72	YES
10/17/2022	14:00	0.57	412	233	9.1	7.6	48	73	YES
10/18/2022	22:00	0.25	484	122	9.5	7.5	44	62	YES
10/19/2022	11:00	0.57	423	243	9.4	7.5	46	71	YES
10/20/2022	16:00	0.57	453	256	9.3	7.6	47	66	YES
10/21/2022	12:00	0.57	424	241	9.1	7.6	47	71	YES
10/22/2022	11:00	0.43	483	209	7.8	7.6	52	62	YES
10/23/2022	14:00	0.68	370	252	7.1	7.6	57	81	YES
10/24/2022	7:00	1.13	501	564	7.0	7.6	60	60	YES
10/25/2022	11:00	0.85	439	375	7.4	7.7	57	68	YES
10/26/2022	13:00	0.73	548	400	7.6	7.5	52	55	YES
10/27/2022	19:00	0.69	444	308	6.3	7.6	59	68	YES
10/28/2022	11:00	0.80	518	412	6.7	7.6	58	58	YES
10/29/2022	19:00	0.83	410	339	7.3	7.6	55	73	YES
10/30/2022	11:00	0.98	432	423	7.6	7.6	55	70	YES
10/31/2022	11:00	1.02	432	439	7.7	7.6	55	70	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME David Jacob

DATE 6-Nov-22 CERT # 3675