

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Nov-22

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.041	0.039	0.036	0.038	0.038	0.04	0.041
2					0.039	0.039	0.039
3	0.04	0.035	0.04	0.038	0.043	0.038	0.043
4				0.038	0.036	0.035	0.038
5	0.041	0.043	0.037			0.043	0.043
6	0.034	0.035	0.035	0.037	0.033	0.033	0.037
7	0.035	0.036	0.035	0.034	0.037	0.031	0.037
8	0.036	0.04	0.039	0.041	0.04	0.037	0.041
9	0.033	0.04	0.042	0.039	0.041	0.04	0.042
10	0.044	0.039	0.042	0.039	0.04	0.041	0.044
11	0.038	0.04	0.04			0.042	0.042
12	0.04	0.042	0.038	0.04	0.041	0.041	0.042
13	0.044	0.039	0.042	0.039	0.04	0.041	0.044
14	0.042	0.039	0.04		0.041	0.041	0.042
15	0.042	0.039	0.04	0.037	0.038	0.041	0.042
16	0.04	0.038	0.037	0.039	0.042		0.042
17				0.039	0.04	0.041	0.041
18	0.04	0.037	0.039	0.041	0.039	0.039	0.041
19	0.038	0.039	0.039	0.039	0.038	0.041	0.041
20	0.04	0.037	0.04	0.041	0.039	0.042	0.042
21	0.038	0.04	0.037			0.038	0.04
22	0.036	0.038	0.04	0.039	0.038	0.036	0.04
23	0.039	0.04	0.04			0.036	0.04
24	0.039	0.039	0.037	0.037	0.041	0.038	0.041
25	0.038	0.039	0.04	0.039	0.038	0.04	0.04
26	0.038	0.041	0.039	0.039	0.038	0.038	0.041
27	0.04	0.039	0.038	0.041		0.036	0.041
28	0.035	0.037	0.036	0.035	0.037	0.039	0.039
29	0.039	0.037	0.038	0.038	0.039	0.042	0.042
30	0.043	0.041	0.1	0.1			0.1
31							

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Nov-22

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
11/1/2022	6:00	0.80	478	381	7.1	7.6	56	63	YES
11/2/2022	16:00	0.75	442	331	5.7	7.5	59	68	YES
11/3/2022	7:00	0.80	463	369	5.5	7.5	61	65	YES
11/4/2022	17:00	0.68	236	161	6.5	7.7	59	127	YES
11/5/2022	10:00	0.58	595	345	5.5	7.5	60	50	YES
11/6/2022	11:00	0.60	312	187	5.5	8.1	74	96	YES
11/7/2022	17:00	1.00	391	392	5.4	7.6	65	77	YES
11/8/2022	15:00	1.01	397	403	5.4	7.6	65	76	YES
11/9/2022	8:00	1.02	411	420	4.8	7.5	66	73	YES
11/10/2022	18:00	1.05	396	415	5.0	7.6	66	76	YES
11/11/2022	16:00	1.03	380	392	4.9	7.6	66	79	YES
11/12/2022	9:00	1.04	355	368	4.8	7.5	66	85	YES
11/13/2022	12:00	1.02	338	346	4.6	7.5	66	89	YES
11/14/2022	18:00	1.01	407	409	4.4	7.5	67	74	YES
11/15/2022	19:00	0.98	426	415	4.3	7.5	67	70	YES
11/16/2022	7:00	0.70	435	306	4.3	7.5	65	69	YES
11/17/2022	16:00	0.50	399	201	3.8	7.4	63	75	YES
11/18/2022	6:00	0.41	454	185	3.5	7.4	64	66	YES
11/19/2022	19:00	0.43	382	164	3.6	7.4	65	79	YES
11/20/2022	9:00	0.44	418	185	3.4	7.4	65	72	YES
11/21/2022	13:00	0.47	380	178	3.8	7.6	68	79	YES
11/22/2022	6:00	0.57	455	261	4.2	7.5	66	66	YES
11/23/2022	17:00	0.44	359	156	4.7	7.5	62	84	YES
11/24/2022	9:00	0.41	361	148	4.9	7.5	60	83	YES
11/25/2022	18:00	0.42	371	155	5.1	7.5	59	81	YES
11/26/2022	10:00	0.41	351	142	4.7	7.5	61	86	YES
11/27/2022	18:00	0.37	388	143	4.7	7.5	60	77	YES
11/28/2022	9:00	0.24	392	95	3.7	7.8	72	77	YES
11/29/2022	18:00	0.85	381	325	3.5	7.8	78	79	YES
11/30/2022	8:00	0.80	407	326	3.5	7.9	79	74	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

4-Dec-22

CERT #

3675