

OHA - Drinking Water Program - Turbidity Monitoring Report form County  
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Jan-23

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.038	0.041	0.04	0.04	0.037	0.04	0.041
2	0.038	0.038	0.038	0.038	0.038	0.038	0.038
3	0.038	0.042	0.042	0.043	0.04	0.039	0.043
4	0.038	0.037	0.038	0.038	0.038	0.038	0.038
5	0.04	0.043	0.036	0.038	0.03	0.038	0.043
6	0.038	0.035	0.042	0.038	0.037	0.04	0.042
7	0.044	0.037	0.04	0.04	0.04	0.034	0.044
8	0.041	0.037	0.04	0.037	0.04	0.04	0.041
9	0.041	0.037	0.039	0.04	0.039	0.039	0.041
10	0.037	0.039	0.041	0.04	0.039	0.038	0.041
11	0.039	0.039	0.037	0.04	0.04	0.036	0.04
12	0.035	0.038	0.04	0.041	0.039	0.039	0.041
13	0.041	0.04	0.041	0.037	0.035	0.038	0.041
14	0.039	0.038	0.039	0.038	0.035	0.037	0.039
15	0.037	0.037	0.038	0.037	0.036	0.034	0.038
16	0.035	0.038	0.037	0.037	0.038	0.038	0.038
17	0.037	0.035	0.037	0.037	0.036	0.039	0.039
18	0.04	0.041	0.04	0.039	0.038	0.041	0.041
19	0.043	0.04	0.041	0.04	0.04	0.038	0.043
20	0.039	0.041	0.042	0.038	0.038	0.038	0.042
21	0.041	0.041	0.041	0.041	0.041	0.041	0.041
22	0.041	0.04	0.039	0.04	0.041	0.038	0.041
23	0.038	0.044	0.038	0.038	0.038	0.038	0.044
24	0.04	0.037	0.038	0.044	0.042	0.042	0.044
25	0.042	0.038	0.04	0.041	0.035	0.035	0.042
26	0.036	0.036	0.035	0.037	0.036	0.037	0.037
27	0.039	0.041	0.041	0.036	0.04	0.036	0.041
28	0.038	0.037	0.039	0.04	0.04	0.041	0.041
29	0.041	0.039	0.042	0.041	0.043	0.035	0.043
30	0.038	0.038	0.041	0.038	0.038	0.038	0.041
31	0.039	0.038	0.035	0.04	0.043	0.041	0.043

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702  
 SURFACE WATER QUALITY DATA

Jan-23

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
1/1/2023	12:00	1.17	221	258	4.3	7.8	78	136	YES
1/2/2023	10:00	1.24	286	356	4.1	8.1	89	105	YES
1/3/2023	9:00	1.69	293	495	4.2	8.0	90	102	YES
1/4/2023	7:00	1.56	316	494	4.1	7.9	83	95	YES
1/5/2023	18:00	1.52	322	491	4.2	7.9	83	93	YES
1/6/2023	7:00	1.52	336	511	4.5	7.9	81	89	YES
1/7/2023	12:00	1.52	305	464	4.7	7.9	80	98	YES
1/8/2023	9:00	1.51	319	482	4.7	7.8	79	94	YES
1/9/2023	8:00	1.50	331	496	4.7	7.8	79	91	YES
1/10/2023	16:00	1.52	339	514	4.7	7.8	78	89	YES
1/11/2023	13:00	1.53	350	537	4.8	7.9	81	86	YES
1/12/2023	17:00	1.46	387	566	5.2	8.0	80	78	YES
1/13/2023	9:00	1.26	319	401	5.3	7.8	72	94	YES
1/14/2023	11:00	1.23	341	420	5.3	7.7	70	88	YES
1/15/2023	10:00	1.18	311	366	4.9	7.7	72	96	YES
1/16/2023	8:00	1.17	382	448	4.8	7.7	71	79	YES
1/17/2023	10:00	1.16	344	399	4.9	7.7	71	87	YES
1/18/2023	10:00	1.18	402	475	4.4	7.7	73	75	YES
1/19/2023	13:00	0.91	306	279	3.7	7.7	74	98	YES
1/20/2023	16:00	0.92	336	308	3.7	7.7	75	89	YES
1/21/2023	10:00	0.95	292	277	3.9	7.7	75	103	YES
1/22/2023	18:00	1.35	390	528	3.8	8.0	88	77	YES
1/23/2023	10:00	1.49	396	590	3.8	7.9	85	76	YES
1/24/2023	18:00	1.33	407	540	4.0	7.7	76	74	YES
1/25/2023	7:00	1.19	395	468	3.9	7.7	77	76	YES
1/26/2023	19:00	1.12	399	445	4.0	7.7	75	75	YES
1/27/2023	11:00	1.04	361	375	4.2	7.7	73	83	YES
1/28/2023	20:00	1.00	355	356	2.6	7.6	78	85	YES
1/29/2023	9:00	1.04	384	399	1.5	7.7	89	78	YES
1/30/2023	18:00	1.09	384	420	2.0	7.7	87	78	YES
1/31/2023	19:00	1.05	436	458	2.7	7.7	82	69	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262  
 SIGNATURE: David Jacob  
 PRINT NAME: David Jacob

DATE: 4-Feb-22      CERT # 3675