

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Feb-23

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.041	0.041	0.04	0.039	0.038	0.041	0.041
2	0.042	0.042	0.04	0.042	0.039	0.042	0.042
3	0.041	0.039	0.041	0.039	0.04	0.038	0.041
4	0.036	0.039	0.036	0.038	0.037	0.036	0.039
5	0.037	0.036	0.041	0.034	0.039	0.037	0.041
6	0.036	0.035	0.04	0.04	0.036	0.038	0.04
7	0.036	0.04	0.041	0.041	0.038	0.039	0.041
8	0.037	0.038	0.038	0.038	0.036	0.038	0.038
9	0.042	0.039	0.037	0.038	0.037	0.035	0.042
10	0.035	0.035	0.036	0.035	0.039	0.038	0.039
11	0.039	0.039	0.037	0.037	0.036	0.038	0.039
12	0.036	0.036	0.038	0.036	0.037	0.036	0.038
13	0.035	0.036	0.038	0.036	0.037	0.036	0.038
14	0.036	0.038	0.04	0.041	0.04	0.036	0.041
15	0.037	0.038	0.036	0.036	0.036	0.044	0.044
16	0.037	0.04	0.038	0.04	0.04	0.037	0.04
17	0.038	0.038	0.035	0.035	0.035	0.035	0.038
18	0.038	0.038	0.038	0.038	0.038	0.038	0.038
19	0.036	0.035	0.036	0.037	0.038	0.041	0.041
20	0.041	0.035	0.037	0.036	0.035	0.036	0.041
21	0.037	0.039	0.041	0.037	0.039	0.042	0.042
22	0.04	0.04	0.039	0.038	0.04	0.041	0.041
23	0.04	0.041	0.04	0.041	0.043	0.042	0.043
24	0.045	0.043	0.04	0.043	0.043	0.04	0.045
25	0.043	0.04	0.039	0.041	0.038	0.039	0.043
26	0.037	0.037	0.039	0.039	0.038	0.036	0.039
27	0.037	0.04	0.038	0.037	0.037	0.037	0.04
28	0.042	0.037	0.039	0.039	0.04	0.04	0.042

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Feb-23

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
2/1/2023	20:00	1.13	351	395	2.7	7.7	83	86	YES
2/2/2023	0:00	1.13	424	479	3.0	7.7	81	71	YES
2/3/2023	14:00	1.12	351	394	3.1	7.7	81	85	YES
2/4/2023	18:00	1.11	412	459	3.6	8.2	93	73	YES
2/5/2023	10:00	1.35	352	475	3.8	7.8	80	85	YES
2/6/2023	9:00	1.10	454	500	3.8	7.8	78	66	YES
2/7/2023	19:00	1.09	391	426	3.9	7.8	78	77	YES
2/8/2023	5:00	0.93	444	414	4.0	7.8	75	68	YES
2/9/2023	19:00	0.93	391	364	4.0	7.8	75	77	YES
2/10/2023	18:00	1.06	441	467	4.1	7.8	76	68	YES
2/11/2023	15:00	0.99	350	347	4.2	7.7	73	86	YES
2/12/2023	9:00	0.97	381	368	4.1	7.7	73	79	YES
2/13/2023	20:00	0.96	366	351	3.5	7.7	76	82	YES
2/14/2023	5:00	0.96	434	418	2.9	7.7	78	69	YES
2/15/2023	11:00	1.01	398	402	2.9	7.7	80	75	YES
2/16/2023	6:00	0.99	423	419	3.0	7.7	78	71	YES
2/17/2023	19:00	1.01	363	365	3.1	8.1	91	83	YES
2/18/2023	9:00	1.19	378	449	3.2	7.7	81	79	YES
2/19/2023	17:00	1.10	358	393	3.4	7.8	80	84	YES
2/20/2023	10:00	1.01	337	341	3.6	7.8	79	89	YES
2/21/2023	10:00	0.94	344	324	3.2	7.8	81	87	YES
2/22/2023	6:00	0.95	378	359	3.0	7.7	80	79	YES
2/23/2023	11:00	0.98	423	413	1.6	7.6	85	71	YES
2/24/2023	21:00	1.00	359	359	1.2	7.7	90	84	YES
2/25/2023	15:00	1.07	338	362	1.3	7.8	93	89	YES
2/26/2023	8:00	1.09	390	426	2.1	7.7	86	77	YES
2/27/2023	10:00	1.12	364	405	2.2	7.8	88	83	YES
2/28/2023	1:00	1.14	396	453	2.4	7.7	85	76	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME: David Jacob

DATE: 3-Mar-23 CERT # 3675