

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Mar-24

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.018	0.018	0.026	0.018	0.058	0.033	0.058
2	0.022	0.03	0.018	0.011	0.011	0.011	0.03
3	0.011	0.011	0.011	0.011	0.011	0.011	0.011
4	0.011	0.011	0.011	0.011	0.011	0.011	0.011
5			0.026	0.011	0.011	0.011	0.026
6	0.011			0.026	0.011	0.026	0.026
7	0.026	0.026	0.011	0.011	0.011	0.011	0.026
8	0.011			0.011	0.026	0.011	0.026
9	0.011	0.011	0.011	0.011	0.011	0.011	0.011
10	0.011	0.011	0.011	0.011	0.026	0.018	0.026
11	0.018	0.024	0.018				0.024
12				0.018	0.018	0.018	0.018
13			0.033	0.028	0.018		0.033
14		0.018	0.018	0.018	0.018	0.017	0.018
15			0.031	0.031	0.018	0.018	0.031
16	0.018	0.018	0.018	0.018	0.018	0.018	0.018
17			0.023	0.018	0.018	0.018	0.023
18		0.018	0.018	0.018	0.018		0.018
19			0.018	0.018	0.018	0.018	0.018
20	0.018	0.018		0.043		0.041	0.043
21	0.018	0.018	0.018	0.018	0.018	0.018	0.018
22	0.018	0.018	0.018	0.018	0.018	0.027	0.027
23	0.018	0.018	0.018	0.018	0.018	0.018	0.018
24	0.018	0.032	0.018	0.018	0.018	0.018	0.032
25	0.018	0.018	0.018	0.018	0.018	0.018	0.018
26	0.018	0.018	0.018	0.018	0.018	0.018	0.018
27	0.032	0.032	0.018	0.018	0.018	0.018	0.032
28	0.018	0.018	0.018	0.018	0.018	0.018	0.018
29	0.033	0.033	0.033	0.032	0.035	0.04	0.04
30			0.04	0.032	0.04	0.033	0.04
31	0.033	0.033	0.032	0.032			0.033

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Mar-24

DATE	TIME	CHLORINE	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	CT REQUIRE	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
3/1/2024	19:00	0.68	1079	735	3.8	7.4	64	28	YES
3/2/2024	7:00	0.80	1031	824	3.7	7.3	63	29	YES
3/3/2024	12:00	0.87	1190	1040	3.5	7.3	65	25	YES
3/4/2024	1:00	0.93	1205	1120	3.3	7.3	67	25	YES
3/5/2024	10:00	0.93	1255	1164	3.4	7.3	66	24	YES
3/6/2024	16:00	0.95	1224	1164	3.1	7.3	68	25	YES
3/7/2024	9:00	0.95	1200	1142	3.1	7.3	68	25	YES
3/8/2024	23:00	1.01	1149	1159	3.1	7.4	70	26	YES
3/9/2024	10:00	1.02	901	921	3.2	7.4	70	33	YES
3/10/2024	16:00	1.06	962	1015	3.4	7.5	71	31	YES
3/11/2024	8:00	1.28	1167	1489	3.6	7.5	74	26	YES
3/12/2024	11:00	1.12	1172	1308	3.7	7.4	68	26	YES
3/13/2024	19:00	1.01	1158	1166	3.7	7.4	68	26	YES
3/14/2024	13:00	1.02	1107	1134	3.6	7.4	69	27	YES
3/15/2024	22:00	1.17	1145	1334	3.7	7.4	69	26	YES
3/16/2024	8:00	1.18	1042	1226	4.0	7.4	68	29	YES
3/17/2024	17:00	1.13	1145	1295	4.3	7.4	66	26	YES
3/18/2024	15:00	1.09	1176	1281	4.5	7.4	64	26	YES
3/19/2024	13:00	0.98	1195	1171	4.8	7.4	62	25	YES
3/20/2024	23:00	0.97	1230	1186	5.1	7.3	60	24	YES
3/21/2024	9:00	0.96	990	950	5.2	7.4	61	30	YES
3/22/2024	17:00	0.83	1000	832	5.3	7.4	60	30	YES
3/23/2024	23:00	0.85	917	775	5.5	7.4	58	33	YES
3/24/2024	9:00	0.85	880	743	5.4	7.4	58	34	YES
3/25/2024	15:00	0.85	940	798	5.4	7.4	58	32	YES
3/26/2024	2:00	0.35	1145	396	5.3	7.7	62	26	YES
3/27/2024	11:00	1.52	1190	1814	5.3	7.6	70	25	YES
3/28/2024	18:00	1.25	1200	1502	5.3	7.4	63	25	YES
3/29/2024	18:00	1.11	1034	1147	5.2	7.4	62	29	YES
3/30/2024	23:00	1.01	1154	1162	5.2	7.4	60	26	YES
3/31/2024	9:00	1.00	1049	1044	5.3	7.4	60	29	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE: David Jacob
 PRINT NAME: David Jacob

DATE: 1-Apr-24 CERT # 3675