

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Oct-24

DAY	Cartridge Turbidity null values = system off A2						WPT	HIGHEST READING
	12-4	4-8	8-12	12-16	16-20	20-24		
1	0.026						0.026	0.026
2	0.026	0.026						0.026
3			0.028	0.026	0.025			0.028
4					0.026	0.026		0.026
5	0.026							0.026
6	0.026	0.027						0.027
7	0.029	0.03					0.041	0.041
8				0.026	0.026	0.026		0.026
9	0.036				0.033	0.043		0.043
10	0.026	0.03						0.03
11			0.033	0.026	0.026	0.026		0.033
12					0.029	0.026		0.029
13	0.026	0.029	0.051	0.033	0.028	0.028		0.051
14	0.026	0.032	0.03	0.026	0.026	0.027		0.032
15	0.037				0.026	0.026		0.037
16	0.026							0.026
17			0.035	0.033	0.043	0.046		0.046
18						0.026		0.026
19	0.026	0.029						0.029
20	0.033	0.029	0.03					0.033
21					0.033	0.033		0.033
22	0.033							0.033
23								0
24						0.026		0.026
25								0
26			0.035	0.027				0.035
27					0.033	0.033		0.033
28				0.033	0.033	0.033		0.033
29	0.035							0.035
30								0
31			0.048					0.048

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Oct-24

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
10/1/2024	0:00	0.64	450	288	9	7.5	47	67	YES
10/2/2024	0:00	0.64	497	317	9	7.6	51	60	YES
10/3/2024	0:00	0.65	448	292	9	7.5	49	67	YES
10/4/2024	1:00	0.64	463	297	8	7.5	50	65	YES
10/5/2024	0:00	0.61	505	306	7	7.6	56	59	YES
10/6/2024	0:00	0.63	467	293	7	7.5	54	64	YES
10/7/2024	0:00	0.71	500	353	8	7.8	57	60	YES
10/8/2024	0:00	0.73	454	333	8	7.5	51	66	YES
10/9/2024	17:00	0.75	467	348	8	7.8	57	64	YES
10/10/2024	0:00	0.75	498	374	7	7.5	55	60	YES
10/11/2024	1:00	0.77	457	353	7	7.8	61	66	YES
10/12/2024	0:00	0.76	423	319	7	7.5	55	71	YES
10/13/2024	0:00	0.76	371	280	6	7.8	65	81	YES
10/14/2024	0:00	0.74	388	288	6	7.5	58	77	YES
10/15/2024	0:00	0.68	485	330	7	7.9	63	62	YES
10/16/2024	0:00	1.25	508	636	7	7.6	60	59	YES
10/17/2024	11:00	0.79	468	371	7	8.0	66	64	YES
10/18/2024	18:00	0.65	443	288	7	7.5	54	68	YES
10/19/2024	2:00	0.58	475	274	7	7.5	54	63	YES
10/20/2024	8:00	0.52	449	234	5	8.1	76	67	YES
10/21/2024	11:00	0.54	446	243	7	8.3	71	67	YES
10/22/2024	7:00	0.45	674	303	7	8.1	65	45	YES
10/23/2024	9:00	0.45	505	226	5	7.4	58	59	YES
10/24/2024	19:00	0.50	501	248	7	6.5	37	60	YES
10/25/2024	20:00	0.56	875	493	7	7.1	46	34	YES
10/26/2024	9:00	0.62	476	295	6	7.2	52	63	YES
10/27/2024	12:00	0.67	475	320	6	7.6	60	63	YES
10/28/2024	16:00	0.54	480	261	5	7.5	61	63	YES
10/29/2024	8:00	0.34	498	171	5	7.2	54	60	YES
10/30/2024	9:00	0.33	701	229	5	7.1	52	43	YES
10/31/2024	10:00	0.45	824	367	6	6.9	46	36	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

3-Nov-24

CERT #

3675