

OHA - Drinking Water Program - Turbidity Monitoring Report form County  
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702 Nov-24

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1				0.057	0.041	0.034	0.057
2	0.047						0.047
3		0.037	0.043	0.052			0.052
4							0
5							0
6							0
7						0.043	0.043
8	0.034						0.034
9							0
10	0.033		0.041	0.033	0.033	0.033	0.041
11	0.033	0.037					0.037
12					0.053	0.041	0.053
13	0.041	0.062	0.137	0.04	0.084	0.057	0.137
14	0.048	0.041	0.048	0.06	0.048	0.041	0.06
15	0.062	0.058					0.062
16						0.062	0.062
17			0.062				0.062
18					0.071	0.048	0.071
19			0.058				0.058
20							0
21				0.07			0.07
22							0
23		0.062	0.07	0.048	0.048		0.07
24						0.066	0.066
25	0.064			0.041		0.041	0.064
26		0.047		0.041			0.047
27					0.062	0.062	0.062
28	0.04		0.04	0.04	0.04	0.04	0.04
29				0.04	0.04		0.04
30	0.04	0.04	0.04	0.04	0.04	0.04	0.04
31							

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas  
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702  
 SURFACE WATER QUALITY DATA

Nov-24

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
11/1/2024	16:00	0.46	443	206	6.7	7.3	50	68	YES
11/2/2024	20:00	0.94	436	411	6.8	7.4	54	69	YES
11/3/2024	0:00	0.73	459	337	6.7	7.5	55	65	YES
11/4/2024	7:00	0.49	432	210	6.7	7.5	55	70	YES
11/5/2024	22:00	0.49	542	263	6.9	7.4	51	55	YES
11/6/2024	23:00	0.54	556	302	6.5	7.4	53	54	YES
11/7/2024	20:00	0.56	483	269	6.4	7.4	54	62	YES
11/8/2024	23:00	0.61	545	332	6.4	7.4	54	55	YES
11/9/2024	20:00	0.70	524	364	6.4	7.4	55	57	YES
11/10/2024	11:00	0.78	495	386	6.7	7.4	54	61	YES
11/11/2024	9:00	0.88	673	589	6.9	7.4	53	45	YES
11/12/2024	11:00	0.76	560	423	6.9	7.4	52	54	YES
11/13/2024	23:00	0.63	648	408	6.9	7.2	48	46	YES
11/14/2024	15:00	0.53	576	303	6.9	7.2	48	52	YES
11/15/2024	23:00	0.83	655	541	6.6	7.2	50	46	YES
11/16/2024	19:00	0.90	523	471	5.8	7.2	54	57	YES
11/17/2024	8:00	0.97	575	557	6.1	7.6	61	52	YES
11/18/2024	16:00	0.85	418	355	5.4	7.4	59	72	YES
11/19/2024	6:00	1.76	624	1098	5.6	7.3	62	48	YES
11/20/2024	18:00	1.32	576	758	5.5	7.2	59	52	YES
11/21/2024	8:00	0.96	580	558	5.4	7.2	57	52	YES
11/22/2024	21:00	0.82	526	432	5.6	7.3	55	57	YES
11/23/2024	12:00	0.76	521	394	5.7	7.5	60	58	YES
11/24/2024	20:00	0.73	541	397	5.8	7.4	57	56	YES
11/25/2024	8:00	0.73	563	411	5.8	7.5	59	53	YES
11/26/2024	8:00	0.68	353	239	5.7	7.5	59	85	YES
11/27/2024	21:00	0.69	493	340	5.6	7.3	55	61	YES
11/28/2024	11:00	0.71	462	330	4.8	7.4	61	65	YES
11/29/2024	10:00	0.75	453	340	4.3	7.4	63	66	YES
11/30/2024	10:00	1.05	462	486	4.0	7.4	67	65	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL <sub>2</sub> RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262  
 SIGNATURE: David Jacob  
 PRINT NAME: David Jacob

DATE: 4-Dec-23      CERT # 3675