

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702 Feb-25

DAY	Cartridge Turbidity null values = system off WPT						HIGHEST READING
	A2						
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.026	0.026	0.026	0.026	0.026	0.026	0.026
2	0.026	0.057		0.04			0.057
3			0.027	0.026	0.026	0.026	0.027
4							0
5				0.026	0.038	0.026	0.038
6					0.033		0.033
7				0.033	0.026	0.026	0.033
8	0.026	0.026	0.026	0.04	0.033		0.04
9			0.04	0.033	0.033	0.033	0.04
10	0.033	0.033	0.04				0.04
11			0.038	0.034		0.038	0.038
12							0
13		0.033	0.033	0.033	0.033	0.033	0.033
14	0.033	0.033	0.033	0.033	0.033	0.033	0.033
15	0.033	0.033	0.033	0.04	0.04	0.041	0.041
16	0.04	0.04	0.04	0.04	0.041	0.05	0.05
17	0.051	0.052	0.051	0.062	0.063	0.131	0.131
18	0.078	0.07	0.069	0.063	0.062	0.062	0.078
19	0.062	0.048	0.062	0.062	0.062	0.062	0.062
20	0.062	0.062	0.053	0.062	0.062	0.048	0.062
21	0.048	0.048	0.048	0.058	0.062	0.078	0.078
22	0.048		0.048			0.062	0.062
23	0.062	0.062	0.082	0.092	0.092	0.121	0.121
24	0.106	0.099	0.092	0.204	0.107	0.084	0.204
25	0.084				0.086	0.07	0.086
26	0.093	0.076	0.062	0.086			0.093
27				0.051	0.062		0.062
28			0.062	0.048	0.048	0.048	0.062
29							0

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Feb-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
2/1/2025	17:00	1.55	467	725	3.4	7.4	74	64	YES
2/2/2025	7:00	1.34	520	699	3.2	7.3	70	58	YES
2/3/2025	14:00	1.33	488	649	2.9	7.3	72	62	YES
2/4/2025	1:00	1.34	640	858	2.9	7.4	75	47	YES
2/5/2025	9:00	1.35	531	716	2.6	7.5	79	57	YES
2/6/2025	0:00	1.37	606	828	2.6	7.4	76	50	YES
2/7/2025	17:00	1.38	471	648	2.5	7.4	77	64	YES
2/8/2025	8:00	1.39	524	728	2.5	7.3	74	57	YES
2/9/2025	17:00	1.41	476	671	2.5	7.5	80	63	YES
2/10/2025	1:00	1.40	617	864	2.2	7.4	79	49	YES
2/11/2025	8:00	0.94	518	487	1.3	7.4	79	58	YES
2/12/2025	0:00	0.94	591	555	1.1	7.3	78	51	YES
2/13/2025	10:00	1.56	485	757	1.1	7.5	90	62	YES
2/14/2025	21:00	0.67	440	296	1.2	7.4	77	68	YES
2/15/2025	16:00	1.61	447	719	1.6	7.3	81	67	YES
2/16/2025	14:00	1.34	437	587	2.0	7.4	79	69	YES
2/17/2025	18:00	1.05	399	418	2.1	7.5	79	75	YES
2/18/2025	8:00	0.87	409	355	2.5	7.4	72	73	YES
2/19/2025	19:00	0.84	418	352	2.8	7.4	71	72	YES
2/20/2025	7:00	0.81	444	359	3.0	7.3	67	68	YES
2/21/2025	19:00	0.83	414	343	3.1	7.4	69	73	YES
2/22/2025	7:00	0.92	507	467	3.5	7.5	71	59	YES
2/23/2025	9:00	0.76	425	322	3.7	7.4	66	71	YES
2/24/2025	0:00	0.61	513	315	3.8	7.4	64	59	YES
2/25/2025	11:00	0.66	464	306	4.2	7.5	65	65	YES
2/26/2025	18:00	1.39	613	851	4.2	7.4	69	49	YES
2/27/2025	9:00	1.47	457	670	4.5	7.5	70	66	YES
2/28/2025	21:00	1.37	465	635	4.7	7.3	64	65	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

2-Mar-25

CERT #

3675