

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Mar-25

DAY	Cartridge Turbidity null values = system off A2						WPT	HIGHEST READING
	12-4	4-8	8-12	12-16	16-20	20-24		NTU
1								0
2				0.053	0.033	0.033		0.053
3		0.036						0.036
4								0
5	0.048	0.048	0.036					0.048
6								0
7		0.048	0.048					0.048
8						0.047		0.047
9	0.035		0.033	0.033				0.035
10								0
11				0.033				0.033
12								0
13					0.033			0.033
14								0
15					0.033	0.033		0.033
16								0
17						0.033		0.033
18								0
19						0.033		0.033
20								0
21						0.045		0.045
22	0.045							0.045
23						0.040		0.04
24			0.041					0.041
25					0.054	0.040		0.054
26	0.040	0.060	0.040					0.06
27					0.042	0.040		0.042
28	0.070		0.061	0.077				0.077
29					0.040	0.033		0.04
30	0.045		0.034					0.045
31						0.070		0.07

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Mar-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
3/1/2025	0:00	1.23	509	628	4.8	7.4	65	59	YES
3/2/2025	10:00	1.19	460	546	5.1	7.5	66	65	YES
3/3/2025	0:00	1.18	531	629	5.2	7.4	63	57	YES
3/4/2025	18:00	1.16	500	582	5.2	7.4	62	60	YES
3/5/2025	7:00	1.16	518	600	4.9	7.5	66	58	YES
3/6/2025	19:00	1.18	476	563	4.7	7.4	65	63	YES
3/7/2025	10:00	1.22	505	615	4.6	7.5	68	59	YES
3/8/2025	20:00	1.22	464	567	4.6	7.4	65	65	YES
3/9/2025	13:00	1.24	440	545	4.6	7.5	68	68	YES
3/10/2025	12:00	1.26	645	814	4.8	7.4	65	47	YES
3/11/2025	9:00	1.27	476	605	4.8	7.5	68	63	YES
3/12/2025	10:00	1.28	676	861	4.9	7.4	65	44	YES
3/13/2025	13:00	1.52	503	761	4.7	7.5	70	60	YES
3/14/2025	19:00	1.37	655	898	4.5	7.4	67	46	YES
3/15/2025	18:00	1.12	465	523	4.2	7.5	69	65	YES
3/16/2025	1:00	0.92	537	492	4.2	7.4	64	56	YES
3/17/2025	18:00	0.80	505	406	4.2	7.4	65	59	YES
3/18/2025	19:00	0.83	557	462	4.2	7.3	62	54	YES
3/19/2025	17:00	0.86	498	428	4.1	7.5	68	60	YES
3/20/2025	5:00	0.93	560	519	4.2	7.4	64	54	YES
3/21/2025	18:00	0.87	478	416	4.3	7.5	67	63	YES
3/22/2025	8:00	0.82	489	403	4.3	7.6	67	61	YES
3/23/2025	18:00	0.82	468	385	4.6	7.6	66	64	YES
3/24/2025	6:00	0.90	526	475	5.1	7.5	63	57	YES
3/25/2025	20:00	0.91	471	430	5.4	7.5	61	64	YES
3/26/2025	7:00	0.88	482	426	5.6	7.5	60	62	YES
3/27/2025	19:00	1.20	491	589	5.8	7.4	60	61	YES
3/28/2025	7:00	1.10	504	555	5.8	7.0	52	60	YES
3/29/2025	16:00	1.05	472	496	5.6	7.1	54	64	YES
3/30/2025	8:00	1.10	484	532	5.4	7.1	54	62	YES
3/31/2025	20:00	1.00	494	494	5.5	7.1	53	61	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
 SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

3-Apr-25

CERT # 3675