

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Apr-25

DAY	Cartridge Turbidity null values = system off A2						WPT HIGHEST READING
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1			0.040				0.040
2							0.000
3			0.054	0.039			0.054
4							0.000
5				0.039	0.033	0.033	0.039
6	0.058						0.058
7				0.040	0.040	0.040	0.040
8							0.000
9				0.070	0.043	0.040	0.070
10	0.053						0.053
11	0.070					0.040	0.070
12	0.062						0.062
13				0.062	0.042		0.062
14	0.062		0.059				0.062
15						0.059	0.059
16	0.040	0.062	0.040				0.062
17						0.061	0.061
18	0.058	0.062	0.040				0.062
19						0.061	0.061
20	0.059	0.062	0.040				0.062
21							0.000
22				0.040	0.040	0.040	0.040
23					0.059	0.062	0.062
24				0.040	0.040	0.040	0.040
25							0.000
26			0.041	0.040	0.067	0.166	0.166
27	0.105	0.057	0.077				0.105
28	0.093	0.062	0.040				0.093
29	0.052						0.052
30	0.040	0.040					0.040

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
SURFACE WATER QUALITY DATA

Apr-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
4/1/2025	8:00	1.10	525	577	5.1	7.1	55	57	YES
4/2/2025	23:00	1.00	595	595	5.2	6.8	50	50	YES
4/3/2025	12:00	1.20	515	617	5.0	7.1	57	58	YES
4/4/2025	8:00	1.00	666	666	4.9	6.8	51	45	YES
4/5/2025	10:00	1.05	473	496	5.1	7.1	55	63	YES
4/6/2025	0:00	1.06	610	646	5.4	7.0	53	49	YES
4/7/2025	19:00	1.04	509	529	5.8	7.1	52	59	YES
4/8/2025	8:00	1.00	781	781	5.9	6.8	47	38	YES
4/9/2025	21:00	1.06	517	548	5.9	7.0	51	58	YES
4/10/2025	0:00	1.12	645	722	6.0	7.0	51	47	YES
4/11/2025	16:00	1.00	520	520	6.3	7.0	49	58	YES
4/12/2025	8:00	1.01	512	519	5.9	7.0	51	59	YES
4/13/2025	16:00	1.04	497	518	5.8	7.1	52	60	YES
4/14/2025	7:00	1.06	557	592	5.8	7.0	50	54	YES
4/15/2025	20:00	1.11	523	583	5.9	6.9	49	57	YES
4/16/2025	9:00	1.04	518	540	6.3	7.0	49	58	YES
4/17/2025	20:00	1.01	543	550	6.3	6.8	46	55	YES
4/18/2025	10:00	1.00	538	537	6.3	7.0	49	56	YES
4/19/2025	20:00	1.00	499	500	6.4	6.9	47	60	YES
4/20/2025	10:00	1.01	496	500	6.3	7.0	50	60	YES
4/21/2025	9:00	1.02	667	683	6.3	6.8	46	45	YES
4/22/2025	12:00	1.01	508	515	6.0	7.1	52	59	YES
4/23/2025	23:00	1.04	605	629	6.2	6.8	47	50	YES
4/24/2025	20:00	1.04	499	519	6.2	7.1	51	60	YES
4/25/2025	0:00	1.09	570	623	6.4	7.0	49	53	YES
4/26/2025	19:00	1.10	456	502	6.8	7.1	50	66	YES
4/27/2025	9:00	1.12	550	619	6.7	7.1	50	54	YES
4/28/2025	18:00	1.15	465	537	6.6	7.1	51	65	YES
4/29/2025	3:00	0.98	561	551	6.8	7.1	49	53	YES
4/30/2025	16:00	0.94	454	425	6.8	7.1	49	66	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

5-May-24

CERT # 3675