

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

May-25

DAY	Cartridge Turbidity null values = system off A2						WPT HIGHEST READING
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.102	0.131	0.149	0.145			0.149
2				0.135	0.103	0.133	0.135
3	0.140			0.120	0.136	0.136	0.140
4	0.099				0.125	0.132	0.132
5	0.125	0.145	0.123	0.135	0.125	0.011	0.145
6	0.011	0.011	0.011	0.011	0.011	0.011	0.011
7	0.011	0.011	0.011	0.011	0.011	0.011	0.011
8	0.011				0.017	0.011	0.017
9	0.011	0.011					0.011
10		0.011	0.011				0.011
11	0.011	0.011	0.011	0.011			0.011
12				0.011	0.011	0.011	0.011
13	0.011						0.011
14					0.012	0.011	0.012
15	0.011					0.026	0.026
16					0.011	0.011	0.011
17	0.013	0.026					0.026
18				0.018	0.011	0.011	0.018
19	0.015	0.015	0.011	0.011	0.011	0.033	0.033
20					0.011	0.011	0.011
21	0.015	0.015	0.032			0.033	0.033
22						0.011	0.011
23	0.026	0.026			0.023	0.033	0.033
24				0.011	0.011	0.011	0.011
25	0.015	0.015	0.061	0.079	0.019	0.033	0.079
26						0.033	0.033
27	0.019	0.015	0.026	0.011	0.015	0.026	0.026
28							0.000
29		0.015	0.013				0.015
30							0.000
31	0.025	0.020	0.017			0.024	0.025

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

May-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
5/1/2025	7:00	0.42	477	200	6.8	7.1	46	63	YES
5/2/2025	16:00	1.30	419	544	7.1	7.1	49	72	YES
5/3/2025	8:00	1.26	479	604	7.3	7.1	49	63	YES
5/4/2025	19:00	1.20	439	527	6.9	7.1	50	68	YES
5/5/2025	8:00	1.18	453	535	6.5	7.1	51	66	YES
5/6/2025	17:00	1.10	456	501	7.0	7.0	48	66	YES
5/7/2025	10:00	1.07	457	490	7.4	7.0	46	66	YES
5/8/2025	16:00	1.06	480	508	7.5	7.0	45	62	YES
5/9/2025	7:00	1.04	520	540	7.5	6.9	45	58	YES
5/10/2025	11:00	1.00	428	430	7.6	6.9	43	70	YES
5/11/2025	9:00	0.91	575	523	7.8	6.9	42	52	YES
5/12/2025	11:00	0.87	471	411	7.5	6.9	43	64	YES
5/13/2025	0:00	0.85	588	497	7.5	6.9	43	51	YES
5/14/2025	17:00	0.82	505	415	7.5	6.8	42	59	YES
5/15/2025	1:00	0.80	594	473	7.4	6.8	42	51	YES
5/16/2025	19:00	0.81	471	382	7.3	6.9	44	64	YES
5/17/2025	5:00	0.74	563	416	7.4	6.9	42	53	YES
5/18/2025	13:00	0.61	464	285	7.0	6.8	42	65	YES
5/19/2025	6:00	0.57	513	294	7.0	7.8	60	59	YES
5/20/2025	15:00	0.63	507	318	7.2	7.6	55	59	YES
5/21/2025	5:00	0.57	576	331	7.1	7.6	54	52	YES
5/22/2025	18:00	0.58	521	302	7.3	7.5	53	58	YES
5/23/2025	16:00	0.60	538	322	7.4	7.5	52	56	YES
5/24/2025	14:00	0.63	405	256	7.6	7.5	52	74	YES
5/25/2025	15:00	0.66	402	266	8.0	7.5	51	75	YES
5/26/2025	22:00	0.70	528	367	8.2	7.4	49	57	YES
5/27/2025	13:00	0.72	454	325	8.0	7.4	50	66	YES
5/28/2025	22:00	0.74	530	391	8.5	7.4	47	57	YES
5/29/2025	17:00	0.74	459	341	9.0	7.4	46	65	YES
5/30/2025	23:00	0.75	475	359	9.0	7.4	46	63	YES
5/31/2025	12:00	0.75	434	325	9.2	7.4	46	69	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

6-Jun-25

CERT # 3675