

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Jun-25

DAY	Cartridge Turbidity null values = system off A2						WPT HIGHEST READING
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1				0.027	0.033	0.029	0.033
2	0.026	0.026	0.020	0.017	0.011	0.011	0.026
3						0.021	0.021
4	0.026	0.011	0.026	0.011	0.027	0.011	0.027
5							0.000
6		0.025	0.011	0.013	0.011	0.011	0.025
7	0.019				0.011	0.011	0.019
8	0.011		0.011	0.011	0.009	0.011	0.011
9	0.011	0.011	0.026	0.011	0.010	0.011	0.026
10	0.011	0.011	0.011	0.011	0.011	0.011	0.011
11							0.000
12				0.027	0.011	0.011	0.027
13	0.014						0.014
14	0.011				0.021	0.011	0.021
15	0.011	0.011	0.012		0.011	0.011	0.012
16	0.018				0.011	0.011	0.018
17	0.011			0.026	0.011	0.011	0.026
18	0.011	0.026				0.011	0.026
19	0.011					0.011	0.011
20	0.011					0.018	0.018
21	0.018	0.015				0.014	0.018
22	0.011	0.015	0.026	0.014	0.026	0.011	0.026
23	0.011	0.026	0.026	0.011	0.011	0.018	0.026
24	0.028	0.018	0.011	0.027	0.022	0.011	0.028
25	0.015					0.013	0.015
26	0.011				0.026	0.011	0.026
27	0.011	0.026	0.024			0.011	0.026
28	0.011	0.026	0.026	0.026	0.011	0.011	0.026
29	0.011	0.026	0.012	0.011	0.019	0.112	0.112
30				0.011	0.008	0.068	0.068
	0	0	0	0	0	0	

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Jun-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
6/1/2025	9:00	0.77	946	733	9.1	7.4	45	32	YES
6/2/2025	18:00	0.77	911	698	8.6	7.4	48	33	YES
6/3/2025	20:00	0.77	825	635	9.0	7.4	45	36	YES
6/4/2025	8:00	0.77	811	621	8.9	7.4	47	37	YES
6/5/2025	20:00	0.76	745	564	9.0	7.4	45	40	YES
6/6/2025	15:00	0.65	643	416	9.3	7.6	49	47	YES
6/7/2025	20:00	0.63	597	373	9.7	7.4	43	50	YES
6/8/2025	14:00	0.53	593	314	10.1	7.3	41	51	YES
6/9/2025	15:00	0.57	572	324	10.6	7.3	40	52	YES
6/10/2025	16:00	0.55	557	306	10.9	7.3	39	54	YES
6/11/2025	21:00	0.55	554	305	10.9	7.3	38	54	YES
6/12/2025	19:00	0.55	543	299	10.1	7.3	41	55	YES
6/13/2025	23:00	0.59	522	306	10.1	7.3	41	57	YES
6/14/2025	20:00	0.60	521	313	9.1	7.3	44	58	YES
6/15/2025	20:00	0.67	512	341	8.4	7.4	47	59	YES
6/16/2025	19:00	0.69	509	353	9.1	7.4	45	59	YES
6/17/2025	17:00	0.72	490	351	9.3	7.4	44	61	YES
6/18/2025	19:00	0.73	489	357	9.6	7.4	44	61	YES
6/19/2025	20:00	0.73	488	357	9.5	7.4	44	61	YES
6/20/2025	23:00	0.75	472	356	9.0	7.4	46	64	YES
6/21/2025	21:00	0.69	468	325	8.5	7.3	46	64	YES
6/22/2025	21:00	0.62	466	289	8.5	7.4	46	64	YES
6/23/2025	19:00	0.61	452	278	8.9	7.4	45	66	YES
6/24/2025	18:00	0.65	452	295	9.3	7.5	46	66	YES
6/25/2025	22:00	0.87	447	387	9.7	7.3	44	67	YES
6/26/2025	19:00	0.77	437	338	9.8	7.3	43	69	YES
6/27/2025	20:00	0.77	430	329	10.0	7.3	42	70	YES
6/28/2025	21:00	0.75	425	320	10.0	7.4	43	71	YES
6/29/2025	16:00	0.75	406	305	10.1	7.4	43	74	YES
6/30/2025	19:00	0.76	366	279	10.6	7.4	41	82	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

7/4/2025

CERT # 3675