

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Jul-25

DAY	Cartridge Turbidity null values = system off A2						WPT HIGHEST READING
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1				0.029	0.026	0.026	0.029
2	0.011			0.026	0.026	0.011	0.026
3	0.011			0.026	0.026	0.011	0.026
4	0.018				0.026	0.011	0.026
5				0.026	0.026		0.026
6			0.013	0.027			0.027
7			0.011	0.020	0.026	0.026	0.026
8					0.026	0.022	0.026
9	0.011			0.026	0.026		0.026
10			0.026	0.026	0.026	0.011	0.026
11			0.011	0.023	0.026	0.011	0.026
12	0.011	0.006	0.011	0.026	0.015	0.011	0.026
13	0.018	0.018	0.013	0.012		0.014	0.018
14	0.011	0.011	0.011	0.015	0.015		0.015
15		0.011	0.011	0.023	0.015	0.011	0.023
16			0.011	0.030	0.026	0.026	0.030
17			0.011	0.023	0.026	0.026	0.026
18		0.011	0.026	0.031	0.026	0.044	0.044
19			0.011	0.016	0.026	0.026	0.026
20			0.011	0.027	0.026	0.026	0.027
21	0.011		0.017	0.026	0.026	0.011	0.026
22	0.011	0.011	0.018	0.015	0.015	0.011	0.018
23	0.011		0.011	0.026	0.015	0.011	0.026
24				0.026	0.026	0.026	0.026
25				0.026	0.026	0.026	0.026
26						0.011	0.011
27			0.011	0.023			0.023
28			0.011	0.015	0.026	0.026	0.026
29			0.011	0.015	0.015	0.026	0.026
30	0.011			0.026	0.026	0.011	0.026
31	0.011		0.011		0.026	0.011	0.026

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
 RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
 SURFACE WATER QUALITY DATA

Jul-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
7/1/2025	10:00	0.77	459	354	11.1	7.4	40	65	YES
7/2/2025	15:00	0.77	429	331	11.3	7.4	39	70	YES
7/3/2025	11:00	0.80	442	353	10.7	7.4	41	68	YES
7/4/2025	14:00	0.83	395	329	10.2	7.4	43	76	YES
7/5/2025	11:00	0.87	359	312	9.8	7.4	45	84	YES
7/6/2025	13:00	0.91	379	345	10.1	7.4	44	79	YES
7/7/2025	11:00	0.91	452	409	10.4	7.4	42	66	YES
7/8/2025	16:00	0.62	396	247	10.8	7.4	40	76	YES
7/9/2025	12:00	0.86	429	369	11.2	7.4	40	70	YES
7/10/2025	15:00	0.85	481	407	11.3	7.4	40	62	YES
7/11/2025	9:00	0.85	302	257	10.8	7.4	42	99	YES
7/12/2025	15:00	0.75	334	250	11.3	7.4	40	90	YES
7/13/2025	18:00	0.75	376	281	11.4	7.4	40	80	YES
7/14/2025	21:00	0.72	426	309	11.9	7.4	38	70	YES
7/15/2025	16:00	0.73	389	283	11.2	7.4	40	77	YES
7/16/2025	13:00	0.73	338	247	11.6	7.6	42	89	YES
7/17/2025	17:00	0.74	371	276	11.6	7.4	38	81	YES
7/18/2025	19:00	0.76	378	289	11.5	7.6	42	79	YES
7/19/2025	17:00	0.77	328	253	11.0	7.8	46	91	YES
7/20/2025	17:00	0.78	403	314	10.8	7.7	46	74	YES
7/21/2025	18:00	0.79	382	302	10.8	7.7	47	79	YES
7/22/2025	16:00	0.79	427	338	10.6	7.8	48	70	YES
7/23/2025	19:00	0.78	400	311	11.0	7.8	47	75	YES
7/24/2025	19:00	0.74	412	304	11.4	7.8	45	73	YES
7/25/2025	17:00	0.74	436	323	11.5	7.9	46	69	YES
7/26/2025	15:00	0.95	385	367	10.9	7.8	48	78	YES
7/27/2025	11:00	0.87	355	308	10.6	7.7	47	85	YES
7/28/2025	10:00	0.83	398	330	10.7	7.7	46	75	YES
7/29/2025	9:00	0.82	381	314	10.8	7.6	45	79	YES
7/30/2025	16:00	0.83	425	354	11.3	7.6	44	71	YES
7/31/2025	10:00	0.83	339	283	11.2	7.7	44	88	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262

SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

4-Aug-24

CERT # 3675