

OHA - Drinking Water Program - Turbidity Monitoring Report form County
Clackamas

TURBIDITY MONITORING REPORT FORM (bag cartridge)

SYSTEM NAME RHODODENDRON WATER ID# 4100702

Aug-25

DAY	Cartridge Turbidity null values = system off A2						WPT HIGHEST READING
	12-4	4-8	8-12	12-16	16-20	20-24	NTU
1	0.026	0.026	0.011	0.011	0.011	0.011	0.026
2	0.011	0.023	0.011	0.010	0.011	0.011	0.023
3	0.011	0.005	0.010	0.026	0.011	0.010	0.026
4		0.026	0.026	0.011	0.002	-0.003	0.026
5		0.026	0.009	-0.004	0.000	-0.004	0.026
6	-0.004	-0.004	-0.003		0.026	0.011	0.026
7	0.011	0.026			0.011	0.008	0.026
8	0.003			0.011	0.004	0.001	0.011
9	-0.004	0.021	-0.002	0.001	0.019	0.011	0.021
10	0.011	0.011	0.011	0.011	0.011	0.010	0.011
11	0.015			0.011	0.006	0.025	0.025
12			0.011	0.013	0.047		0.047
13		0.011	0.011	0.011	0.011	0.011	0.011
14	0.011	0.011		0.011	0.011	0.011	0.011
15	0.011	0.026			0.011	0.011	0.026
16		0.019	0.011	0.011	0.011	0.022	0.022
17	0.011	0.011		0.026	0.011	0.011	0.026
18	0.011			0.011	0.011	0.011	0.011
19			0.011	0.011	0.011	0.026	0.026
20	0.011	0.011	0.011		0.011	0.010	0.011
21	0.011	0.010		0.011	0.014		0.014
22			0.012	0.017	0.026	0.026	0.026
23	0.026	0.017	0.018	0.017	0.017	0.018	0.026
24				0.017	0.017	0.023	0.023
25	0.026	0.026	0.017	0.017	0.025		0.026
26		0.018	0.017	0.017	0.023	0.018	0.023
27	0.017		0.026	0.023	0.021	0.024	0.026
28		0.026	0.019	0.019	0.025		0.026
29	0.026	0.024	0.018	0.026	0.018	0.020	0.026
30			0.017	0.015	0.018	0.026	0.026
31			0.013	0.011	0.013	0.026	0.026

OHA - Drinking Water Program - Turbidity Monitoring Report form County Clackamas
RHODODENDRON WATER ASSOCIATION PWS ID# 4100702
SURFACE WATER QUALITY DATA

Aug-25

DATE	TIME	NE RESIDU	CONTACT TIME	ACTUAL CT	WATER TEMP	WATER PH	REQUIRE D	PEAK HOURLY FLOW	CT MET
		PPM	minutes	C x T	C°	-log(h)	reg equ	GPM	YES/NO
8/1/2025	17:00	0.84	381	320	11.0	7.7	45	79	YES
8/2/2025	10:00	0.85	458	391	10.9	7.7	46	66	YES
8/3/2025	16:00	0.90	422	378	10.9	7.7	47	71	YES
8/4/2025	16:00	0.90	439	394	10.5	7.8	48	68	YES
8/5/2025	12:00	0.91	375	339	10.2	7.3	41	80	YES
8/6/2025	19:00	0.91	519	472	10.6	7.2	39	58	YES
8/7/2025	14:00	0.85	473	400	10.5	7.4	42	63	YES
8/8/2025	12:00	0.84	476	399	10.1	7.5	45	63	YES
8/9/2025	8:00	1.01	425	430	10.3	7.4	44	71	YES
8/10/2025	16:00	0.95	348	330	10.8	7.4	42	86	YES
8/11/2025	17:00	0.92	307	281	11.5	7.5	41	98	YES
8/12/2025	12:00	0.90	359	322	12.0	7.5	40	84	YES
8/13/2025	8:00	0.89	487	432	12.2	7.6	41	62	YES
8/14/2025	14:00	0.91	429	391	11.8	7.6	42	70	YES
8/15/2025	12:00	0.96	475	457	11.5	7.6	43	63	YES
8/16/2025	11:00	0.93	473	439	11.5	7.6	43	63	YES
8/17/2025	17:00	0.92	474	438	11.3	7.6	43	63	YES
8/18/2025	17:00	0.95	531	505	11.1	7.6	43	56	YES
8/19/2025	11:00	0.99	486	480	10.7	7.6	45	62	YES
8/20/2025	18:00	0.86	415	358	10.8	7.5	43	72	YES
8/21/2025	17:00	0.86	425	364	10.2	7.5	45	71	YES
8/22/2025	15:00	0.35	354	123	10.9	7.5	40	85	YES
8/23/2025	17:00	1.00	423	421	11.5	7.5	41	71	YES
8/24/2025	14:00	0.88	409	361	11.9	7.5	39	73	YES
8/25/2025	12:00	0.85	412	351	12.2	7.4	38	73	YES
8/26/2025	10:00	0.83	439	366	12.3	7.5	38	68	YES
8/27/2025	16:00	0.83	450	373	12.5	7.5	39	67	YES
8/28/2025	14:00	0.84	387	323	12.1	7.5	40	78	YES
8/29/2025	17:00	0.85	420	355	12.0	7.6	41	71	YES
8/30/2025	11:00	0.87	420	364	11.6	7.6	42	71	YES
8/31/2025	12:00	0.86	405	350	11.3	7.6	42	74	YES
95% of Daily Turbidity Readings < 1 ntu					yes	CL ₂ RESID AT Entry Point ALWAYS >0.2 MG/L			yes
All Daily Turbidity Readings < 5 NTU					yes	CT's Met Everyday?			yes

phone 503-310-9262
SIGNATURE:

David Jacob

PRINT NAME

David Jacob

DATE

9/1/2025

CERT # 3675